






SITE PLAN (1)  
SCALE: 1"=200'  
A-0




5661 COLUMBIA PKWY, SUITE 200  
FALLS CHURCH, VA 22041-2868  
TEL: (703) 671-6000  
FAX: (703) 671-6300

SITE ADDRESS:  
2700 MARTIN LUTHER KING JR. AVE, SE  
WASHINGTON, DC 20020

[illegible]


$$\begin{pmatrix} 1 \\ A-1 \end{pmatrix}$$


**at&t**  
7150 STANDARD DR  
HANOVER, MD 21075



|                |     |
|----------------|-----|
| DRAWING NUMBER | REV |
| A-1            | 1   |

|                 |          |                             |           |     |
|-----------------|----------|-----------------------------|-----------|-----|
| 3               |          |                             |           |     |
| 2               |          |                             |           |     |
| 1               | 03-29-12 | EQUIPMENT LOCATION          | DR        | CDM |
| 0               | 02-13-12 | ZONING DRAWINGS             | GMW       | CDM |
| A               | 01-26-12 | PRELIMINARY ZONING DRAWINGS | GMW       | CDM |
| NO.             | DATE     | REVISIONS                   | BY        | CHK |
| SCALE: AS SHOWN |          | DESIGNED B. DUNN            | DRAWN GMW |     |

|          |          |          |                                                              |
|----------|----------|----------|--------------------------------------------------------------|
| 02-13-12 | GWOLOZYN | 10:14:40 | Y:/Drawings - 2011/AT&T/Rowlands/Fort Stiemmer/Zoning/T1.dwg |
|----------|----------|----------|--------------------------------------------------------------|



**at&t**

FORT SLEMMER\_ROOSEVELT HIGH SCHOOL  
10136181\_4072

## VICINITY MAP

**DIRECTION:**

FROM 7150 STANDARD DR. TAKE THE 21076 HAVEN SOUTHWEST ON STANDARD DR TOWARD PARKWAY DR. 0.4 MI. TURN LEFT TOWARD PARKWAY DR. 75 FT. PAVE THE 1ST RIGHT ONTO PARK CR. DR. 0.4 MI. TURN LEFT ONTO COCA COLA DR. 0.3 MI. MERGE ONTO MO-100 W VA. KEEP LEFT TO ELLICOTT CITY 1.7 MI. TAKE EXIT 5A-58 FOR I-95 TOWARD BALTIMORE/WASHINGTON 0.2 MI. RAMP TO THE FORK AND MERGE ONTO I-95 S 16.0 MI. TAKE EXIT 27 FOR I-495 W TOWARD SILVER SPRING 0.9 MI. MERGE ONTO I-495 3.3 MI. TAKE EXIT 30 TO MERGE ONTO US-29 S/DOLEVILLE, MD/COLUMBIA PVE TOWARD SILVER SPRING, CONTINUE TO FOLLOW DOLEVILLE RD 2.3 MI. AT THE TRAFFIC CIRCLE, TAKE THE 2ND RIGHT ONTO US-29 S/DOLEVILLE, MD/COLUMBIA PVE TOWARD SILVER SPRING, CONTINUE TO FOLLOW DOLEVILLE RD 2.3 MI. AT THE TRAFFIC CIRCLE, TAKE THE 2ND RIGHT ONTO US-29 S/DOLEVILLE, MD/COLUMBIA, ENTERING DISTRICT OF COLUMBIA 0.8 MI. TURN RIGHT ONTO GEORGIA AVE 2.9 MI. SLIGHT RIGHT ONTO KANSAS AVE N 180 FT. TAKE THE 1ST RIGHT ONTO UPSHUR ST N. DESTINATION WILL BE ON THE RIGHT 0.1 MI.

## APPLICABLE BUILDING CODES AND STANDARDS

SUBCONTRACTOR'S WORK SHALL COMPLY WITH ALL APPLICABLE NATIONAL, STATE, AND LOCAL CODES AS ADOPTED BY THE LOCAL AUTHORITY HAVING JURISDICTION (AHJ) FOR THE LOCATION. THE EDITION OF THE AHJ ADOPTED CODES AND STANDARDS IN EFFECT ON THE DATE OF CONTRACT AWARD SHALL GOVERN THE DESIGN.

BUILDING CODE:  
INTERNATIONAL BUILDING CODE (IBC 2009)

ELECTRICAL CODE:  
NATIONAL ELECTRICAL CODE, (NEC 2008)

SUBCONTRACTOR'S WORK SHALL COMPLY WITH THE LATEST EDITION OF THE FOLLOWING STANDARDS:

AMERICAN CONCRETE INSTITUTE (ACI) 318, BUILDING CODE REQUIREMENTS FOR STRUCTURAL CONCRETE.

AMERICAN INSTITUTE OF STEEL CONSTRUCTION (AISC), MANUAL OF STEEL CONSTRUCTION, ASD, NINTH EDITION.

TELECOMMUNICATIONS INDUSTRY ASSOCIATION (TIA)  
TIA 222-F, STRUCTURAL STANDARDS FOR STEEL ANTENNA TOWER AND ANTENNA SUPPORTING STRUCTURES.  
TIA 607, COMMERCIAL BUILDING GROUNDING AND BONDING REQUIREMENTS FOR TELECOMMUNICATIONS.


INSTITUTE FOR ELECTRICAL AND ELECTRONICS ENGINEERS (IEEE)  
IEEE 81, GUIDE FOR MEASURING EARTH RESISTIVITY, GROUND IMPEDANCE, AND EARTH SURFACE POTENTIALS OF A GROUND SYSTEM.  
IEEE 1100 (1999) RECOMMENDED PRACTICE FOR POWERING AND GROUNDING OF ELECTRONIC EQUIPMENT.  
IEEE C82.41, RECOMMENDED PRACTICES ON SURGE VOLTAGES IN LOW VOLTAGE AC POWER CIRCUITS (FOR LOCATION CATEGORY "CS"  
AND "HIGH SURFACE EXPOSURE").

TELCORDIA, CR-1275, GENERAL INSTALLATION REQUIREMENTS.

TELCORDIA CR-1503, COAXIAL CABLE CONNECTIONS.

ANSI T1.311, FOR TELECOM - DC POWER SYSTEMS - TELECOM, ENVIRONMENTAL PROTECTION.

FOR ANY CONFLICTS BETWEEN SECTIONS OF LISTED CODES AND STANDARDS REGARDING MATERIAL, METHODS OF CONSTRUCTION, OR OTHER REQUIREMENTS, THE MOST RESTRICTIVE REQUIREMENT SHALL GOVERN. WHERE THERE IS CONFLICT BETWEEN A GENERAL REQUIREMENT AND A SPECIFIC REQUIREMENT, THE SPECIFIC REQUIREMENT SHALL GOVERN.



SCALE: 1"=2000'

## UTILITY INFORMATION

|        |         |                |
|--------|---------|----------------|
| POWER: | PEPCO   | (202) 833-7500 |
| TELCO: | VERIZON | (202) 833-7500 |

## DRAWING INDEX

REV

|     |                           |   |
|-----|---------------------------|---|
| T-1 | TITLE SHEET               | 1 |
| A-0 | SITE PLAN                 | 1 |
| A-1 | COMPOUND PLAN & ELEVATION | 1 |

## NOTES

NOTE: MAGNETIC DECLINATION - 10° 49'W CHANGING BY 0' 0"W PER YEAR AS OF 01/26/12

TECHNICAL DOCUMENT 24782-432-A3-EF-00001 "COMPANION PACKAGE DETAIL", DATED 11/23/09 FOR USE IN THE BAKA MARKET ONLY (NSR)




5661 COLUMBIA PIKE, SUITE 200  
FALLS CHURCH, VA 22041-2868  
TEL: (703) 671-6000  
FAX: (703) 671-6300

FORT SLEMMER ROOSEVELT HIGH SCHOOL  
10136181\_4072

SITE ADDRESS:  
2700 MARTIN LUTHER KING JR. AVE, SE  
WASHINGTON, DC 20030

[illegible]

03-29-12 DAVID 12.03.04 Y:\Drawings - 2011\AT&T\Rawlands\Fort Slemmer/Zoning - Rev 1\AD.dwg



SITE PLAN 1  
SCALE: 1"=200' A-0

**BC**  
architects  
engineers


5601 COLUMBIA PIKE, SUITE 200  
FALLS CHURCH, VA 22041-2868  
TEL: (703) 671-6000  
FAX: (703) 671-6300

FORT SLEMMER-ROOSEVELT HIGH SCHOOL  
10136181\_4072

SITE ADDRESS:  
2700 MARTIN LUTHER KING JR. AVE, SE  
WASHINGTON, DC 20020



| NO.             | DATE     | REVISIONS                   | BY        | CHK | APP'D |
|-----------------|----------|-----------------------------|-----------|-----|-------|
| 3               |          |                             |           |     |       |
| 2               |          |                             |           |     |       |
| 1               | 03-29-12 | EQUIPMENT LOCATION          | DR        | CDM | BMG   |
| 0               | 02-13-12 | ZONING DRAWINGS             | GMW       | CDM | BMG   |
| A               | 01-26-12 | PRELIMINARY ZONING DRAWINGS | GMW       | CDM | BMG   |
| NO.             | DATE     | REVISIONS                   | BY        | CHK | APP'D |
| SCALE: AS SHOWN |          | DESIGNED B. QUINN           | DRAWN GMW |     |       |



BC ARCHITECTS ENGINEERS  
FALLS CHURCH, VA

SITE PLAN

| DRAWING NUMBER | REV |
|----------------|-----|
| A-0            | 1   |

