

Meridith Moldenhauer

From: James (Killette & Associates) <killetteandassoc@aol.com>
Sent: Friday, October 12, 2012 5:55 PM
To: Meridith Moldenhauer
Cc: mpsl6255@gmail.com
Subject: 3602 16th Street, NW
Attachments: DOC PDF

Hi Meredith,

I met with Bill Schoon, Public Space Manager today. He informed me that Brown Street has a street distribution of four feet, six inches. This is the maximum distance allowed for a projection. The portion of the structure that extends beyond the property line at Brown Street is approximately two feet. Mr. Schoon informed me that this could be approved as a projection since it does not exceed the maximum street distribution. (see attached site plan).

Thank you,

James Killette

KILLETTE & ASSOCIATES

202-257-2237