


GOVERNMENT OF THE DISTRICT OF COLUMBIA
 DEPARTMENT OF CONSUMER AND REGULATORY AFFAIRS
 OFFICE of the ZONING ADMINISTRATOR



PLAN CORRECTION LIST

Job #	Address	Review Engineer	Date
B1309068 E	2709 36 th St NW	Mamadou Ndaw: mamadou.ndaw@dc.gov	8-29-13

CHANGES REQUIRED PRIOR TO APPROVAL

No.	Comments

For Zoning Approval:

2nd Zoning Review:

BZA approval is required for noncompliance with §403.2, maximum lot occupancy and §412.3 minimum pervious surface in R-1-B.

1st Zoning Review: 8-20-13

1. Please apply for a subdivision to convert the tax lot into a record lot.
2. The proposed addition does not comply with maximum lot occupancy requirements
3. Please depict the dimensions on elevation drawings (sheets A-1 thru A-3).
4. Additional comments may follow.

Return Application and specifications to File Room