

The diagram consists of two parts: a plan view and a section view.

PLAN VIEW: This view shows the top of the barrel filter assembly. It is a rectangular structure divided into three main sections. The leftmost section is labeled "SILTED WATER" and has a "3" / ROSE TO TO ACT AS BAFFLES(TYP)" on its left side. The middle section is labeled "BURLEAP BAG FILTER". The rightmost section is labeled "FILTERED WATER" and has a "3" / ROSE TO TO ACT AS BAFFLES(TYP)" on its right side. The ends of the barrels are labeled "ENDS OF BARRELS CUT TO ACT AS BAFFLES(TYP)".

SECTION: This view shows a cross-section of the barrel filter assembly. It is a circular barrel resting on a "2X4 CRADLE". The top of the barrel is labeled "12"(APPROX.) CLEANOUT SLOT" and "CUT OUT (INTERIOR WALLS ONLY)". The bottom of the barrel is labeled "APPROX. 3/4 DIA. BARREL END TO ACT AS BAFFLE".

STANDARD SYMBOL: A rectangular box containing the letters "PST".

THE TOP OF THE STANDPIPE SHOULD EXTEND AT LEAST 12" TO 18" ABOVE THE TOP OF THE PIT OR ABOVE STANDING WATER.

CLEAN WATER DISCHARGE

SUMP LINE TO PUMP

EXISTING GROUND LINE

STANDPIPE WRAPPED IN 1/2" HARDWARE CLOTH AND GEOTEXTILE CLASS E

SIDE SLOPE (VARIES)

12" - 36" DIAMETER PERFORATED CORRUGATED METAL OR PVC PIPE

WATER TIGHT CAP OR PLATE

CLEAN GRVEL OR ASKITE M-43 #1 AGGREGATE FILL

CROSS SECTION

STANDARD SYMBOL

SP

PLACE 12" BASE OF M-43 #1 STONE BEFORE INSTALLING STANDPIPE.

CONSTRUCTION SPECIFICATIONS

1. PIT DIMENSIONS ARE VARIABLE, WITH THE MINIMUM DIAMETER BEING 2 TIMES THE STANDPIPE DIAMETER.
2. THE STANDPIPE SHOULD BE CONSTRUCTED BY PERFORMING A 12" TO 24" DIAMETER CORRUGATED OR PVC PIPE. THEN WRAPPING WITH 1/2" HARDWARE CLOTH AND GEOTEXTILE CLASS E. THE PERFORATIONS SHOULD BE 1/2" X 8" SLOTS OR 1" DIAMETER HOLES.
3. A BASE OF FILTER MATERIAL CONSISTING OF CLEAN GRVEL OR #57 STONE SHOULD BE PLACED IN THE PIT TO A DEPTH OF 12". AFTER INSTALLING THE STANDPIPE, THE PIT SURROUNDING THE STANDPIPE SHOULD THEN BE BACKFILLED WITH THE SAME FILTER MATERIAL.
4. THE STANDPIPE SHOULD EXTEND 12" TO 18" ABOVE THE LIP OF THE PIT OR THE RISER CREST ELEVATION (BASIN DRAINING ONLY) AND THE FILTER MATERIAL SHOULD EXTEND 3" MINIMUM ABOVE THE ANTICIPATED STANDING WATER ELEVATION.

1. THE CONTRACTOR SHALL CONDUCT OPERATIONS AND MAINTAIN THE PROJECT SITE SO AS TO MINIMIZE THE CREATION AND DISPERSION OF DUST. DUST CONTROL SHALL BE USED THROUGHOUT THE WORK AT THE AREA.
2. THE CONTRACTOR MUST PROVIDE CLEAN WATER, FREE FROM SALT, OIL AND OTHER DELETERIOUS MATERIAL, TO BE USED FOR ON-SITE DUST CONTROL.
3. THE CONTRACTOR SHALL SUPPLY WATER SPRAYING EQUIPMENT CAPABLE OF ACCESSING ALL WORK AREAS.
4. THE CONTRACTOR SHALL IMPLEMENT STRICT DUST CONTROL MEASURES DURING ACTIVE CONSTRUCTION PERIODS ON-SITE. THESE CONTROL MEASURES WILL GENERALLY CONSIST OF WATER APPLICATIONS THAT SHALL BE APPLIED A MINIMUM OF ONCE PER DAY DURING DRY WEATHER OR MORE OFTEN AS REQUIRED TO PREVENT DUST EMISSIONS.
5. FOR WATER APPLICATION TO UNDISTURBED SOIL SURFACES, THE CONTRACTOR SHALL:
 - A. APPLY WATER WITH EQUIPMENT CONSISTING OF TANK, SPRAY BAR, PUMP WITH DISCHARGE PRESSURE GAUGE.
 - B. ADJUST SPRAY BAR HEIGHT, NOZZLE SPACING AND SPRAY PATTERN TO PROVIDE COMPLETE COVERAGE OF GROUND WITH WATER.
 - C. DISPERSE WATER THROUGH NOZZLES ON SPRAY BAR AT 20 PSI (137.8 KPA), MINIMUM. KEEP AREAS DAMP WITHOUT CREATING MUDSPREAD CONDITIONS SUCH AS PONDING.
6. FOR WATER APPLICATION TO SOIL SURFACES DURING DEMOLITION AND/OR EXCAVATION, THE CONTRACTOR SHALL:
 - A. APPLY WATER WITH EQUIPMENT CONSISTING OF A TANK, PUMP WITH DISCHARGE GAUGE, HOSES AND MIST NOZZLES.
 - B. LOCATE TANK AND SPRAYING EQUIPMENT SO THAT THE ENTIRE EXCAVATION AREA CAN BE MOISTENED WITHOUT INTERFERING WITH DEMOLITION AND/OR EXCAVATION EQUIPMENT OR OPERATIONS. KEEP AREAS DAMP WITHOUT CREATING MUDSPREAD CONDITIONS SUCH AS PONDING.
 - C. APPLY WATER SPRAY IN A MANNER TO PREVENT MOVEMENT OF SPRAY BEYOND THE SITE BOUNDARIES.

CONSTRUCTION SEQUENCING INVOLVES CREATING AND FOLLOWING A WORK SCHEDULE THAT BALANCES THE TIMING AND SEQUENCING OF LAND DISTURBANCE ACTIVITIES, SUCH AS EARTHWORK, AND THE INSTALLATION OF EROSION AND SEDIMENTATION CONTROL (ESC) MEASURES. THE OBJECTIVES OF CONSTRUCTION SEQUENCING IS TO REDUCE ON-SITE EROSION AND OFF-SITE SEDIMENTATION THAT MIGHT AFFECT THE WATER QUALITY OF NEARBY WATER BODIES.

THE GENERAL CONSTRUCTION SCHEDULE AND THE CONSTRUCTION SEQUENCING SCHEDULE SHOULD BE COMPATIBLE. KEY CONSTRUCTION ACTIVITIES AND ASSOCIATED ESC MEASURES ARE LISTED BELOW.

DESIGNATE SITE ACCESS:
STABILIZE EXPOSED AREAS WITH GRAVEL AND/OR TEMPORARY VEGETATION. IMMEDIATELY APPLY STABILIZATION TO AREAS EXPOSED THROUGHOUT SITE DEVELOPMENT.

PROTECT RUNOFF OUTLETS AND CONVEYANCE SYSTEMS:
INSTALL PRINCIPLE SEDIMENT TRAPS, FENCES, AND BASINS PRIOR TO GRADING; STABILIZE STREAM BANKS AND INSTALL STORM DRAINS, CHANNELS, ETC.

LAND CLEARING:
MARK TREES AND BUFFER AREAS FOR PRESERVATION.

SITE STABILIZATION:
INSTALL TEMPORARY AND PERMANENT SEEDING, MULCHING, SOILING, RPPAP, ETC.

BUILDING CONSTRUCTION AND UTILITIES INSTALLATION:
INSTALL ADDITIONAL ESC MEASURES AS NEEDED DURING CONSTRUCTION.

LANDSCAPING AND FINAL SITE STABILIZATION:
THIS IS THE LAST CONSTRUCTION PHASE. REMOVE ALL TEMPORARY CONTROL MEASURES. INSTALL TOPSOIL, TREES AND SHRUBS, PERMANENT SEEDING, MULCHING, SOILING, RPPAP, ETC. STABILIZE ALL OPEN AREAS INCLUDING BORROW AND SPOIL AREAS.

<u>SILT FENCE DESIGN CHART</u>			
<u>SLOPE STEEPNESS</u>	<u>(MAXIMUM) SLOPE LENGTH</u>	<u>(MAXIMUM) SLOPE LENGTH</u>	<u>(MAXIMUM) SLOPE LENGTH</u>
FLATTER THAN 50:1	UNLIMITED	UNLIMITED	
50:1 TO 10:1	125 FT.	1,000 FT.	
10:1 TO 5:1	100 FT.	750 FT.	
5:1 TO 3:1	60 FT.	500 FT.	
3:1 TO 2:1	40 FT.	250 FT.	
2:1 AND STEEPER	25 FT.	125 FT.	

NOTE: IN AREAS OF LESS THAN 2% SLOPE AND SANDY SOILS (USDA GENERAL CLASSIFICATION SYSTEM), CLASSES AS MAXIMUM SLOPE LENGTH AND SILT FENCE LENGTH WILL BE UNLIMITED. IN THESE AREAS SILT FENCE MAY BE THE ONLY PERIMETER CONTROL REQUIRED.

CONSTRUCTION SPECIFICATIONS

- FENCE POST SHALL BE A MINIMUM OF 30' LONG DRIVEN 18" MINIMUM INTO THE GROUND. WOOD POST SHALL BE 1 1/2" SQUARE (MINIMUM) CUT, OR 1 3/4" DIAMETER (MINIMUM) ROUND AND SHALL BE OF SOUND QUALITY HARDWOOD. STEEL POST SHALL BE STANDARD T OR U SECTION WEIGHING NOT LESS THAN 1.00 POUND PER LINEAR FOOT.
- GEOTEXTILE SHALL BE FASTENED SECURELY TO EACH FENCE POST WITH WIRE TIES OR NAILS TO TOP AND MID-SECTION AND SHALL MEET THE FOLLOWING REQUIREMENTS FOR GEOTEXTILE CLASS P:

TENSILE STRENGTH	50 LBS/IN (MIN)	TEST: MSMT 308
TENSILE MODULUS	20 LBS/IN (MIN.)	TEST: MSMT 308
FLOW RATE	0.3 GAL. FT/MIN (MAX)	TEST: MSMT 322
FILTERING EFFICIENCY	75% (MIN)	TEST: MSMT 322
- WHERE ENDS OF GEOTEXTILE FABRIC COME TOGETHER, THEY SHALL BE OVERLAPPED, FOLDED AND STAPLED TO PREVENT SEDIMENT BYPASS.
- SILT FENCE SHALL BE INSPECTED AFTER EACH RAINFALL EVENT AND MAINTAINED WHEN BULGES OCCUR OR WHEN SEDIMENT ACCUMULATION REACHES 50% OF THE FABRIC HEIGHT.

10' MAXIMUM CENTER

36' MIN. FENCE POST, DRIVEN A MINIMUM OF 6' INTO GROUND

10' MIN. HEIGHT OF GEOTEXTILE CLASS F

6' MIN. DEPTH IN GROUND

WOVEN WIRE FENCE

FLOW FLOW

PERSPECTIVE VIEW

36' MIN. FENCE POST LENGTH

FLOW

EMBED GEOTEXTILE CLASS F A MIN. OF 6' VERTICALLY INTO THE GROUND

FENCE POST SECTION

GROUND

UNDISTURBED GROUND

FENCE POST DRIVEN A MIN. OF 6' INTO THE GROUND

CROSS SECTION

TOP VIEW

POST

SECTION A

SECTION B

STAPLE

STAPLE

STANDARD SYMBOL

6'

JOINING TWO ADJACENT SECTIONS

1. LENGTH - MIN. OF 50' RAMP X 30' RAMP FOR SINGLE RESIDENCE LOT.
2. WIDTH - 10' MINIMUM, SHOULD BE FLARED AT THE EXISTING ROAD TO PROVIDE A TURNING RADIUS.
3. GEOTEXTILE FABRIC (FILTER CLOTH) SHALL BE PLACED OVER THE EXISTING GROUND PRIOR TO PLACING STONE.
4. STONE - CRUSHED AGGREGATE (2" TO 3") OR RECLAIMED OR RECYCLED CONCRETE EQUIVALENT SHALL BE PLACED AT LEAST 6" DEEP OVER THE LENGTH AND WIDTH OF THE ENTRANCE.
5. SURFACE WATER - ALL SURFACE WATER FLOWING TO OR DIVERTED TOWARD CONSTRUCTION ENTRANCES SHALL BE PIPED THROUGH THE ENTRANCE, MAINTAINING POSITIVE DRAINAGE. PIPE INSTALLED THROUGH THE STABILIZED CONSTRUCTION ENTRANCE SHALL BE PROTECTED WITH A MOUNTABLE BERM WITH 2:1 SLOPES AND MIN. OF 6" OF STONE OVER THE PIPE. PIPE HAS TO BE SIZED ACCORDING TO THE DRAINAGE, WHEN THE SLOPE IS LOCATED AT A HIGH SPOT AND HAS NO DRAINAGE TO CONVEY, A PIPE WILL NOT BE NECESSARY. PIPE SHOULD BE SIZED ACCORDING TO THE AMOUNT OF RUNOFF TO BE CONVEYED. A 6" MIN. WILL BE REQUIRED.
6. LOCATION - A STABILIZED CONSTRUCTION ENTRANCE SHALL BE LOCATED AT EVERY POINT WHERE CONSTRUCTION TRAFFIC ENTERS OR LEAVES A CONSTRUCTION SITE. VEHICLES LEAVING THE SITE MUST TRAVEL OVER THE ENTIRE LENGTH OF THE STABILIZED CONSTRUCTION ENTRANCE.
7. MAINTENANCE - THE ENTRANCE SHALL BE MAINTAINED IN CONDITION WHICH WILL PREVENT TRACKING OR FLOWING OF SEDIMENT ONTO PUBLIC RIGHTS-OF-WAY. THE WAY MAY REQUIRE PERIODIC TOP DRESSING WITH ADDITIONAL STONE AS CONDITIONS DEMAND AND REPAIR AND/OR CLEAN-UP OF ANY MEASURES USED TO TRAP SEDIMENT. ALL SEDIMENT SCALED, DROPPED, WASHED OR TRACKED ONTO PUBLIC RIGHTS-OF-WAY MUST BE REMOVED IMMEDIATELY.
8. WASHING - WHEELS SHALL BE CLEANED TO REMOVE SEDIMENT PRIOR TO ENTERING ONTO PUBLIC FRONT-OF-WAY WHEN WASHING IS REQUIRED. IT SHALL BE DONE ON AN AREA STABILIZED WITH STONE WHICH DRAINS INTO A APPROVED SEQUESTER TRAPPING DEVICE.
9. PERIODIC INSPECTION AND NEEDED MAINTENANCE SHALL BE PROVIDED AFTER EACH RAIN.

[illegible]

Diagram illustrating a stone weir structure with various components labeled:

- 3/4" x 1 1/2" STONE
- 6" MAX. SPACING OF 2" X 4" SPACERS
- 2" X 4" ANCHORS
- FILTER CLOTH
- WIRE MESH
- 2" X 4" WEIR
- 2" X 4" SPACER
- MAX. DRAINAGE AREA = 1/4 ACRE
- 2" MINIMUM LENGTH
- 2" X 4" WEIR
- SANDBAG OR ALTERNATE WEIGHT
- 3/4" x 1 1/2"
- STONE
- FILTER CLOTH
- WIRE MESH TO STOP M. DRAIN
- 2" X 4" SPACER
- STANDARD SYMBOL
- CIP

CONSTRUCTION SPECIFICATIONS

1. ATTACH A CONTINUOUS PIECE OF WIRE MESH 30" MIN. WIDTH BY THROAT LENGTH PLUS 4" TO THE 2"x4" WEIR (MEASURING THROAT LENGTH) PLUS 2" AS SHOWN ON THE STANDARD DRAWING
2. PLACE A CONTINUOUS PIECE OF GEOTEXTILE CLASS E THE SAME DIMENSIONS AS THE WIRE MESH OVER THE WIRE MESH AND SECURELY ATTACH IT TO THE 2"x4" WEIR.
3. SECURELY NAIL THE 2"x4" WEIR TO A 6" LONG VERTICAL SPACER TO BE LOCATED BETWEEN THE WEIR AND THE INLET FACE (MAX. 4" APART).
4. PLACE THE ASSEMBLY AGAINST THE INLET THROAT AND NAIL (MIN. 2" LENGTHS OF 2"x4" TO THE TOP OF THE WEIR AT SPACER LOCATIONS). THE 2"x4" ANCHORS SHALL EXTEND ACROSS THE INLET TOP AND BE HELD IN PLACE BY SANDBAGS OR ALTERNATE WEIGHT.
5. THE ASSEMBLY SHALL BE PLACED SO THAT THE END SPACERS ARE A MIN. 1' (31 in) BEYOND BOTH ENDS OF THE THROAT OPENING.

FORM THE 12"x12" WIRE MESH AND THE GEOTEXTILE FABRIC TO THE CONCRETE OUTLET AND AGAINST THE FACE OF THE CURB ON BOTH SIDES OF THE INLET. PLACE CLEAN 3/4"x1/2" STONE OVER THE WIRE MESH AND GEOTEXTILE IN SUCH A MANNER TO PREVENT WATER FROM ENTERING THE INLET UNDER OR AROUND THE GEOTEXTILE.

THIS TYPE OF PROTECTION MUST BE INSPECTED FREQUENTLY AND THE FILTER CLOTH AND STONE REPLACED WHEN CLOGGED WITH SEDIMENT.

ASSURE THAT STORM FLOW DOES NOT BYPASS THE INLET BY INSTALLING A TEMPORARY EARTH OR ASPHALT CLOSURE TO DIRECT FLOW TO THE INLET.

The technical drawing consists of two views: a Plan/Cut Away View and a Cross Section.

Plan/Cut Away View: This view shows the top-down layout of the assembly. It features a triangular area of Geotextile Class E on the left, which transitions into a rectangular area of 3/4" - 1 1/2" stone on the right. The stone area is 6' wide and 6' high. The Geotextile Class E is labeled with a leader line.

Cross Section: This view shows the assembly from the side. It illustrates the 3/4" - 1 1/2" stone layer on top of the Inlet Grate. The Inlet Grate is supported by wire ties. The Geotextile Class E is shown underneath the stone layer, with a 6" overlap indicated. The wire ties are labeled with a leader line.

Legend: A box contains the symbol for the Inlet Grate (a rectangle with a cross inside) and the text "STANDARD SYMBOL" and "A-10".

MAX. DRAINAGE AREA = 1/4 ACRE

CONSTRUCTION SPECIFICATIONS

1. LIFT GRATE AND WRAP WITH GEOTEXTILE CLASS E TO COMPLETELY COVER ALL OPENINGS THEN SET GRATE BACK IN PLACE.
2. PLACE 3/4" TO 1 1/2" STONE, 4"-6" THICK ON THE GRATE TO SECURE THE FABRIC AND PROVIDE ADDITIONAL FILTRATION.

A line drawing diagram showing a truck positioned in a vehicle wash area. The truck is facing left, with its rear end in the wash area. A worker in a hard hat and safety gear is standing to the right of the truck, holding a hose. The wash area is defined by a series of vertical panels. A flow of water is indicated by an arrow pointing from the worker towards the truck. The area is labeled "VEHICLE WASH AREA". To the left of the truck, there is a "STABILIZED CONSTRUCTION ENTRANCE" marked with a series of small circles.