


FRONT GRADE

Revised Plans – Proposed

DCRA Notes Existing Grade as 4'2" Establishes
Lower Level Front Grade as Basement. Drawing
Misrepresents Grade as 3'11" A0201 (12/17/14)




FRONT GRADE

Revised Plans – Proposed

DCRA Notes Existing Grade as 4'2" Establishes Lower Level Front Grade as Basement.

Drawing Misrepresents Grade as 3'11"


A0202 (12/16/14)



REAR GRADE

Revised Plans – Proposed

Misrepresents Retaining Wall as 3'10". Grade would be 5'3" if constructed as permitted at 30" height
A0201 (12/17/14)



REAR GRADE

Revised Plans - Proposed

Misrepresents Retaining Wall as 3'10"

Grade would be 5'3" if constructed as permitted at
30" height - A0202 (12/17/14)



REAR GRADE
Revised Plans - Proposed
Misrepresents Retaining Wall as 3'10"
Grade would be 5'3" if constructed at
permitted at 30" height
A0202 (12/17/14)

