



Home My Account Apply for a Permit Kiosk Locations Map/Info Lookup tool FAQ Public Space Fees
Search Permit Application Sign out

Welcome Taher Kh
If this is not you, [click here](#)

Comments from Public Space Permit Office/Reviewing Agencies for application tracking number: 111738

Back

Please enter criteria:

Tracking Number

Application Start Date

Work Location Address

Tracking Number

Details

111738

Details

111735

Details

111323

Public Space Permit Office Comments:

Notes ID	Comment Date	Comments	Commented By
152640	8/25/2015 8:46:14 PM	The Office of the Zoning Administrator provided the following comment for this application via email: the parking space shown on the applicant's plat does not conform with the zoning regulations. The applicant will be required to either build a garage or seek BZA relief. We would like a hold to be placed on the DDOT permit so that it is not issued until after the applicant has provided conforming parking. This will be included in the record for the Public Space Committee's consideration.	Matthew Marcou
152490	8/25/2015 10:50:01 AM	Applicant need to upload revised drawings to address reviewers comments	Kisha Allen

Comments from Reviewing Agencies:

Comment Date	Comments	Commented By
7/13/2015 9:29:58 AM	All operations shall comply with District Department of Transportation Standard Specifications for Highways and Structures and design and engineering manual 2014 DDOT 'Gold Book. Inspector to be present during work time, restored to existing condition. The temporary patches see DDOT DWG. NO. 617.25The pavement restoration sees DDOT DWG NO. 215.01 And DDOT DWG. NO. 215.02	Ali Zamani
7/24/2015 2:23:48 PM	Please revise to include a 6' sidewalk in front of property along Burbank Street and D Street. Also, the retaining wall needs to be added as a work detail and type description to the permit. Please label the height of the retaining wall and pull it back from the newly built sidewalk.	Evelyn Israel
	1. Identify symbol highlighted on FINALIZED mark-up in d.TOPS - ECP Sheet C1. Apply for a construction/excavation permit if this is a retaining wall. 2. Show all trees to remain between the building restriction line and property line on the plans. 3. Add the following note to the plan - Install	