

**EXHIBIT E**

**ESTIMATED QUANTITIES OF POTABLE WATER,  
SANITARY SEWAGE AND STORM WATER**

Domestic water demand: 6" service, 600 gpm

Fire protection water demand: 8" service, 1000 gpm

Sanitary drainage: Four 8" sanitary building drains  
peak flow ea-240 gpm  
average flow ea-50 gpm.

Storm drainage: Four 15" storm building drains  
peak flow ea-1050 gpm.

# 4470513\_v1