GOVERNMENT OF THE DISTRICT OF COLUMBIA
FIRE AND EMERGENCY MEDICAL SERVICES DEPARTMENT
WASHINGTON, D.C. 20001

MEMORANDUM

TO: Maxine Brown-Roberts, AICP
Development Review Specialist, OP

FROM: Bruce Cowan BC
Fire Marshal

DATE: February 20, 2002

SUBJECT: BZA Application 16815 (Adams Alley, LLC)
2412-17th Street, N.W., (Square 2566, Lot 95)

The D.C. Fire and EMS Department has reviewed the above application and recommend approval of the project, provided the owner agrees to install a fire sprinkler system in the entire building. The sprinkler system shall be in stalled in accordance with the District of Columbia Building Code. In addition, residential sprinklers shall be installed in the residential portion of the building.

If you have any questions regarding this review, please contact Acting Captain William F. Guffey of my staff. He may be reached at 727-1614.

BZA
Case No. 16815
Exhibit No. 53

Board of Zoning Adjustment
District of Columbia
CASE NO.16815
EXHIBIT NO.53