GOVERNMENT OF THE DISTRICT OF COLUMBIA
FIRE AND EMERGENCY MEDICAL SERVICES DEPARTMENT
WASHINGTON, D.C. 20001

MEMORANDUM

TO: Andrew Altman
Director
Office of Planning

FROM: Bruce Cowan
Fire Marshal

DATE: March 22, 2002

SUBJECT: BZA Application No. 16827

RECEIVED
D.C. OFFICE OF ZONING
2002 MAR 25 AM 9:12

The Fire and EMS Department has reviewed your application and made a site visit to the reference property.

The Fire and EMS Department is concerned about the rear access to the property. However, we will approve your request if the applicant is willing to install a fire sprinkler system in the new addition as well as the existing building.

The issue concerning the exterior stairs is a building code issue and should be addressed by officials at the Department and Consumer and Regulatory Affairs.

If you have any questions, please contact my office at 727-3659.

BZA
Case No. 16827
Exhibit No. 40

Board of Zoning Adjustment
District of Columbia
CASE NO.16827
EXHIBIT NO.40

Government Of The District Of Columbia
Office Of Planning

★ ★ ★

Facsimile Transmittal Sheet

To: Elaine Booth **From:** ARTHUR JACKSON

Company: OFFICE OF ZONING **Date:** MARCH 25, 2002

Fax Number: 727-6072 **Number Of Pages Including Cover:** 2

Phone Number: 727-6311 **Sender's Phone Number:** 202-442-8809

Re: AGENCY RESPONSE CONCERNING BZA 16827

☐ Urgent X For Review ☐ Please Comment ☐ Please Reply ☐ Please Recycle

Please add the attached response to the BZA mailing. Contact me at 442-8809 with questions.

RECEIVED
D.C. OFFICE OF ZONING
2002 MAR 25 AM 9:12

801 North Capitol Street NE ▪ Suite 4000 ▪ Washington DC 20002
Main 202-422-7600 ▪ Fax 202-422-7638