GOVERNMENT OF THE DISTRICT OF COLUMBIA
FIRE AND EMERGENCY MEDICAL SERVICES DEPARTMENT
WASHINGTON, D.C. 20001



RECEIVED
D.C. OFFICE OF ZONING
2002 APR -9 PM 5:11

MEMORANDUM

TO: Andrew Altman
Director
Office of Planning

FROM: Bruce Cowan BC
Fire Marshal

DATE: April 5, 2002

SUBJECT: BZA Application No. 16859

The D.C. Fire and EMS Department has reviewed the above application.

We recommend approval, provided a fire sprinkler system and automatic fire detector system is installed in accordance with the D.C. Construction Codes.

If you have any questions regarding this review, please contact Lieutenant William F. Guffey of my staff. He may be reached at 727-1614.

BZA
Case No. 16859
Exhibit No. 27

Board of Zoning Adjustment
District of Columbia
CASE NO.16859
EXHIBIT NO.27

Government Of The District Of Columbia
Office Of Planning

★ ★ ★

Facsimile Transmittal Sheet

To: Elaine Booth **From:** ARTHUR JACKSON

Company: OFFICE OF ZONING **Date:** APRIL 8, 2002

Fax Number: 727-6072 **Number Of Pages Including Cover:** 2

Phone Number: 727-6311 **Sender's Phone Number:** 202-442-8809

Re: AGENCY RESPONSE CONCERNING BZA 16859

☐ Urgent ☒ For Review ☐ Please Comment ☐ Please Reply ☐ Please Recycle

Please add the attached response to the BZA mailing. Contact me at 442-8809 with questions.

RECEIVED
D.C. OFFICE OF ZONING
2002 APR -9 PM 5:11

801 North Capitol Street NE ▪ Suite 4000 ▪ Washington DC 20002
Main 202-422-7600 ▪ Fax 202-422-7638