Apexenvironmental, inc.

Table 1
Confirmed ACM

2900 Albemarle Street, NW
Washington, DC

ACBM Description	Friable (Yes/No)	ACM Location	% Asbestos by PLM	Quantity
Green 9- by 9-inch floor tile	No	Basement - family room, hallway, bedroom	9% Chrysotile	994 s.f.
Green and white linoleum flooring	No	Basement - kitchen	20% Chrysotile	124 s.f.
Black roof coating on gable seams	No	Roof	12% Chrysotile	200 l.f
Brown vibration joint on duct	No	Basement - laundry room	75% Chrysotile	4 l.f.

[1]s.f. = square feet.
[2]l.f. = linear feet.

R548;Zuckerman-01.doc(10058.010);dta/vrc/swm

Board of Zoning Adjustment
District of Columbia
CASE NO. 16982
EXHIBIT NO. 32A3

DCRA/OSEC/FOIA #248513/BLRA/L. Douglas
Permit Intake and Issuance Branch
Application (d): 44 of 57

Apexenvironmental, inc.

Table 2

Homogeneous Material List
(All materials suspected of being asbestos-containing)

2900 Albemarle Street, NW
Washington, DC

Description of Material Type	Friable (Yes/No)	Location	Sample Numbers	ACM[a] (Yes/No)	Quantity
Surfacing Materials					
Wall and ceiling plaster	Yes	Select areas of building	B8, B24, B25, B26, B27, B28, B29, B30	No	—
Texture plaster	Yes	Select areas of building	B12, B/13, B/14, B/15	No	—
Thermal System Insulation (TSI) Materials					
Non detected	NA	NA	NA	NA	NA
Miscellaneous Materials					
Green 9- by 9-inch floor tile	No	Basement - family room, hallway, bedroom	B1, B3	Yes	994 s.f.
Black floor mastic associated with green 9- by 9-inch floor tile	No	Basement - family room, hallway, bedroom	B2, B4	No	—
White 12- by 12-inch ceiling tile	Yes	Basement –family room	B5, B6	No	—
Drywall	Yes	Select areas of building	B7, B20	No	—
Window caulk	No	Exterior windows	B9, B35	No	—
Green and white linoleum flooring	No	Basement - kitchen	B10, B16	Yes	124 s.f.
Floor mastic under green and white linoleum flooring	No	Basement - kitchen	B11, B17	No	—
Blue 9- by 9-inch floor tile	No	Northeast corridor	B21, B18	No	—
Floor mastic under blue 9- by 9-inch floor tile	No	Northeast corridor	B19, B22	No	—
Canvas wrap on duct	No	First floor closet	B23, B31	No	—
Duct mastic	No	Attic	B32, B33	No	—
Black roof coating on gable seams	No	Roof	B34	Yes	200 l.f.
White vibration joint on duct	No	Basement - laundry room	B36	No	—
Brown vibration joint on duct	No	Basement - laundry room	B37	Yes	4 l.f.

[a]ACBM: A homogenous material is considered asbestos-containing if any one sample is found to contain greater than one percent asbestos.
[b]s.f. – square feet.
[c]l.f. – linear feet.

R548:Zuckerman-01.doc(10058.010);dta/vre/swm

Apexenvironmental, inc.

Appendix A

Bulk Sample Laboratory Report

EMSL Analytical, Inc.
10768 Baltimore Avenue
Beltsville, MD 20705
Phone: (301) 937-5700 Fax: (301) 937-5701

Attn.: Steve Simmons
Apex Environmental, Inc. (MD)
16860 Crabbs Branch Way
Suite 200
Rockville, MD 20855

Tuesday, April 02, 2002

Ref Number: MD021688

POLARIZED LIGHT MICROSCOPY (PLM)

Performed by EPA 600/R-93/116 Method*

Project: 2900 Albermarle Wash, DC

Sample	Location	Appearance	Sample Treatment	ASBESTOS % Type	NON-ASBESTOS % Fibrous	% Non-Fibrous
040102SZCEN 8001	9x9 flr. tile green	Green Fibrous Heterogeneous	Teased/Dissolved	9% Chrysotile	3% Cellulose	30% Quartz 58% Other
040102SZCEN 8002	Black mastic	Black Fibrous Heterogeneous	Teased/Dissolved	None Detected	10% Cellulose	90% Other
040102SZCEN 8003	9x9 flr. tile green	Green Fibrous Heterogeneous	Teased/Dissolved	8% Chrysotile	3% Cellulose	30% Quartz 59% Other
040102SZCEN 8004	Black mastic	Black Fibrous Homogeneous	Teased/Dissolved	None Detected	10% Cellulose	90% Other
040102SZCEN 8005	12x12" ceiling tile	Tan Fibrous Homogeneous	Teased/Dissolved	None Detected	75% Cellulose	25% Other
040102SZCEN 8006	12x12" ceiling tile	Cream/Tan Fibrous Heterogeneous	Teased/Dissolved	None Detected	70% Cellulose	30% Other

Comments: For all obviously heterogeneous samples easily separated into subsamples, and for layered samples, each component is analyzed separately. Also, "# of Layers" refers to number of separable subsamples.

* NY samples analyzed by ELAP 198.1 Method.

Russell Meyer
Analyst

Approved Signatory

Disclaimer: PLM has been known to miss asbestos in a small percentage of samples which contain asbestos. Thus negative PLM results cannot be guaranteed. EMSL suggests that samples reported as <1% or none detected be tested with either SEM or TEM. The above test report relates only to the items tested. This report may not be reproduced, except in full, without written approval by EMSL. The above test must not be used by the client to claim product endorsement by NVLAP nor any agency of the United States Government. Laboratory is not responsible for the accuracy of results when requested to physically separate and analyze layered samples.

DCRA/OSEC/FOIA #248513/BLRA/L. Douglas
Permit Intake and Issuance Branch
Application (d) : 47 of 57

104

EMSL Analytical, Inc.

10768 Baltimore Avenue
Beltsville, MD 20705
Phone: (301) 937-5700 Fax: (301) 937-5701

EMSL

Attn.: Steve Simmons
Apex Environmental, Inc. (MD)
15850 Crabbs Branch Way
Suite 200
Rockville, MD 20855

Tuesday, April 02, 2002

Ref Number: MD021668

POLARIZED LIGHT MICROSCOPY (PLM)

Performed by EPA 600/R-93/116 Method*

Project: 2900 Albermarle Wash, DC

Sample	Location	Appearance	Sample Treatment	ASBESTOS % Type	NON-ASBESTOS % Fibrous	% Non-Fibrous
040102SZCEN B007	Drywall	Tan/White Fibrous Heterogeneous	Teased/Dissolved	None Detected	30% Cellulose	30% Ca Carbonate 30% Gypsum 10% Other
040102SZCEN B008(SKIM COAT)	Plaster	White Non-Fibrous Heterogeneous	Teased/Dissolved	None Detected	None Detected	50% Ca Carbonate 50% Other
040102SZCEN B008(BROWN COAT)	Plaster	Grey Non-Fibrous Heterogeneous	Teased/Dissolved	None Detected	None Detected	55% Perlite 45% Other
040102SZCEN B009	Window caulk	Grey/White Non-Fibrous Heterogeneous	Teased/Dissolved	None Detected	None Detected	100% Other
040102SZCEN B010	Linoleum green white tan	Grey/Olive/Beige Fibrous Heterogeneous	Teased/Dissolved	20% Chrysotile	20% Cellulose	60% Other
040102SZCEN B011	Linoleum mastic	Black/Yellow Non-Fibrous Heterogeneous	Teased/Dissolved	None Detected	None Detected	100% Other

Comments: For all obviously heterogeneous samples easily separated into subsamples, and for layered samples, each component is analyzed separately. Also, "# of Layers" refers to number of separable subsamples.

* NY samples analyzed by ELAP 198.1 Method.

Russell Meyer
Analyst

Approved Signatory

Disclaimer: PLM has been known to miss asbestos in a small percentage of samples which contain asbestos. Thus negative PLM results cannot be guaranteed. EMSL suggests that samples reported as <1% or none detected be tested with either SEM or TEM. The above test report relates only to the items tested. This report may not be reproduced, except in full, without written approval by EMSL. The above test must not be used by the client to claim product endorsement by NVLAP nor any agency of the United States Government. Laboratory is not responsible for the accuracy of results when requested to physically separate and analyze layered samples.

2

EMSL Analytical, Inc.

10768 Baltimore Avenue
Beltsville, MD 20705
Phone: (301) 937-5700 Fax: (301) 937-5701

EMSL

Attn.: Steve Simmons
Apex Environmental, Inc. (MD)
15850 Crabbs Branch Way
Suite 200
Rockville, MD 20855

Tuesday, April 02, 2002

Ref Number: MD021868

POLARIZED LIGHT MICROSCOPY (PLM)

Performed by EPA 600/R-93/116 Method*

Project: 2900 Albermarle Wash, DC

Sample	Location	Appearance	Sample Treatment	ASBESTOS % Type	NON-ASBESTOS % Fibrous	% Non-Fibrous
0401028ZCEN B012	Drywall with plaster	Tan/White/Blue Fibrous Heterogeneous	Teased/Dissolved	None Detected	30% Cellulose	30% Ca Carbonate 30% Gypsum 10% Other
0401028ZCEN B013	Drywall with plaster	Cream Non-Fibrous Heterogeneous	Teased/Dissolved	None Detected	None Detected	40% Perlite 60% Other
0401028ZCEN B014	Drywall with plaster	Cream Non-Fibrous Heterogeneous	Teased/Dissolved	None Detected	None Detected	40% Perlite 60% Other
0401028ZCEN B015(DRYWALL)	Textured plaster	Tan/White Fibrous Heterogeneous	Teased/Dissolved	None Detected	30% Cellulose	30% Ca Carbonate 30% Gypsum 10% Other
0401028ZCEN B015(PLASTER)	Textured plaster	Cream Non-Fibrous Heterogeneous	Teased/Dissolved	None Detected	None Detected	45% Perlite 55% Other
0401028ZCEN B016	Tan creme white linoleum	Grey/Tan Fibrous Heterogeneous	Teased/Dissolved	None Detected	25% Cellulose	75% Other

Comments: For all obviously heterogeneous samples easily separated into subsamples, and for layered samples, each component is analyzed seperately... Also, "# of Layers" refers to number of separable subsamples.

* NY samples analyzed by ELAP 198.1 Method.

Russell Meyer
Analyst

Approved Signatory

Disclaimer: PLM has been known to miss asbestos in a small percentage of samples which contain asbestos. Thus negative PLM results cannot be guaranteed. EMSL suggests that samples reported as <1% or none detected be tested with either SEM or TEM. The above test report relates only to the items tested. This report may not be reproduced, except in full, without written approval by EMSL. The above test must not be used by the client to claim product endorsement by NVLAP nor any agency of the United States Government. Laboratory is not responsible for the accuracy of results when requested to physically separate and analyze layered samples.

DCRA/OSEC/FOIA #248513/BLRA/L. Douglas
Permit Intake and Issuance Branch
Application (d) :49 of 57

106

EMSL Analytical, Inc.
10768 Baltimore Avenue
Beltsville, MD 20705
Phone: (301) 937-5700 Fax: (301) 937-5701

EMSL

Attn.: Steve Simmons
Apex Environmental, Inc. (MD)
16850 Crabbs Branch Way
Suite 200
Rockville, MD 20855

Tuesday, April 02, 2002

Ref Number: MD021668

POLARIZED LIGHT MICROSCOPY (PLM)

Performed by EPA 600/R-93/116 Method*

Project: 2900 Albermarle Wash, DC

Sample	Location	Appearance	Sample Treatment	ASBESTOS % Type	NON-ASBESTOS % Fibrous	% Non-Fibrous
0401028ZCEN B017	Mastic	Yellow Non-Fibrous Homogeneous	Teased/Dissolved	None Detected	None Detected	100% Other
0401028ZCEN B018	9x9 blue flr. tile	Blue Non-Fibrous Heterogeneous	Teased/Dissolved	None Detected	None Detected	100% Other
0401028ZCEN B019	Mastic	Brown Fibrous Homogeneous	Teased/Dissolved	None Detected	15% Cellulose	85% Other
0401028ZCEN B020	Drywall joint compound	Gray/Tan Fibrous Heterogeneous	Teased/Dissolved	None Detected	30% Cellulose	30% Ca Carbonate 30% Gypsum 10% Other
0401028ZCEN B021	9x9 flr. tile	Blue Non-Fibrous Heterogeneous	Teased/Dissolved	None Detected	None Detected	100% Other
0401028ZCEN B022	Mastic	Brown Fibrous Homogeneous	Teased/Dissolved	None Detected	15% Cellulose	85% Other

Comments: For all obviously heterogeneous samples easily separated into subsamples, and for layered samples, each component is analyzed separately. Also, "# of Layers" refers to number of separable subsamples.

*NY samples analyzed by ELAP 198.1 Method.

Russell Meyer
Analyst

Approved
Signatory

Disclaimer: PLM has been known to miss asbestos in a small percentage of samples which contain asbestos. Thus negative PLM results cannot be guaranteed. EMSL suggests that samples reported as <1% or none detected be tested with either SEM or TEM. The above test report relates only to the items tested. This report may not be reproduced, except in full, without written approval by EMSL. The above test must not be used by the client to claim product endorsement by NVLAP nor any agency of the United States Government. Laboratory is not responsible for the accuracy of results when requested to physically separate and analyze layered samples.

EMSL Analytical, Inc.
10768 Baltimore Avenue
Beltsville, MD 20705
Phone: (301) 937-5700 Fax: (301) 937-5701

Attn.: Steve Simmons
Apex Environmental, Inc. (MD)
*6650 Crabbs Branch Way
Suite 200
Rockville, MD 20855

Tuesday, April 02, 2002

Ref Number: MD021688

POLARIZED LIGHT MICROSCOPY (PLM)

Performed by EPA 600/R-93/116 Method*

Project: 2900 Albermarle Wash, DC

Sample	Location	Appearance	Sample Treatment	ASBESTOS % Type	NON-ASBESTOS % Fibrous	% Non-Fibrous
040102SZCEN B023	Canvas duct covering	Tan Fibrous Homogeneous	Teased/Dissolved	None Detected	95% Cellulose	5% Other
040102SZCEN B024	Plaster	Beige Non-Fibrous Heterogeneous	Teased/Dissolved	None Detected	None Detected	35% Quartz 65% Other
040102SZCEN B025(SKIM COAT)	Plaster	White Non-Fibrous Heterogeneous	Teased/Dissolved	None Detected	None Detected	60% Ca Carbonate 40% Other
040102SZCEN B025(BROWN COAT)	Plaster	Grey Non-Fibrous Heterogeneous	Teased/Dissolved	None Detected	None Detected	45% Quartz 55% Other
040102SZCEN B026(SKIM COAT)	Plaster	Tan/White Fibrous Heterogeneous	Teased/Dissolved	None Detected	30% Cellulose	30% Ca Carbonate 40% Other
040102SZCEN B026(BROWN COAT)	Plaster	Grey Non-Fibrous Heterogeneous	Teased/Dissolved	None Detected	None Detected	45% Quartz 55% Other

Comments: For all obviously heterogeneous samples easily separated into subsamples, and for layered samples, each component is analyzed separately. Also, "# of Layers" refers to number of separable subsamples.

* NY samples analyzed by ELAP 198.1 Method.

Russell Meyer
Analyst

Approved Signatory

Disclaimer: PLM has been known to miss asbestos in a small percentage of samples which contain asbestos. Thus negative PLM results cannot be guaranteed. EMSL suggests that samples reported as <1% or none detected be tested with either SEM or TEM. The above test report relates only to the items tested. This report may not be reproduced, except in full, without written approval by EMSL. The above test must not be used by the client to claim product endorsement by NVLAP nor any agency of the United States Government. Laboratory is not responsible for the accuracy of results when requested to physically scrape and analyze layered samples.

DCRA/OSEC/FOIA #248513/BLRA/L. Douglas
Permit Intake and Issuance Branch
Application (d) : 51 of 57

108

APR-02-2002 12:04PM TEL:3019373701 ID:APEX ENVIRONMENTAL PAGE:006 R=97%

EMSL Analytical, Inc.

10768 Baltimore Avenue
Beltsville, MD 20705
Phone: (301) 937-5700 Fax: (301) 937-5701

Attn.: Steve Simmons
Apex Environmental, Inc. (MD)
15850 Crabbs Branch Way
Suite 200
Rockville, MD 20855

Tuesday, April 02, 2002

Ref Number: MD021668

POLARIZED LIGHT MICROSCOPY (PLM)

Performed by EPA 600/R-93/116 Method*

Project: 2900 Albermarle Wash, DC

Sample	Location	Appearance	Sample Treatment	ASBESTOS % Type	NON-ASBESTOS % Fibrous	% Non-Fibrous
040102BZCEN B027(SKIM COAT)	Plaster	White Non-Fibrous Heterogeneous	Teased/Dissolved	None Detected	None Detected	60% Ca Carbonate 40% Other
040102BZCEN B027(BROWN COAT)	Plaster	Grey Non-Fibrous Heterogeneous	Teased/Dissolved	None Detected	None Detected	40% Quartz 60% Other
040102BZCEN B028(SKIM COAT)	Plaster	Tan/White Non-Fibrous Heterogeneous	Teased/Dissolved	None Detected	None Detected	60% Ca Carbonate 40% Other
040102BZCEN B028(BROWN COAT)	Plaster	Grey Non-Fibrous Heterogeneous	Teased/Dissolved	None Detected	None Detected	40% Quartz 60% Other
040102BZCEN B029(SKIM COAT)	Plaster	White/Tan/Blue Non-Fibrous Heterogeneous	Teased/Dissolved	None Detected	None Detected	60% Ca Carbonate 60% Other
040102BZCEN B029(BROWN COAT)	Plaster	Grey Non-Fibrous Heterogeneous	Teased/Dissolved	None Detected	None Detected	50% Quartz 50% Other

Comments: For all obviously heterogeneous samples easily separated into subsamples, and for layered samples, each component is analyzed separately. Also, "# of Layers" refers to number of separable subsamples.

* NY samples analyzed by ELAP 198.1 Method.

Russell Meyer
Analyst

Approved Signatory

Disclaimer: PLM has been known to miss asbestos in a small percentage of samples which contain asbestos. Thus negative PLM results cannot be guaranteed. EMSL judgems that samples reported as <1% or none detected be tested with either SEM or TEM. The above test report relates only to the items tested. This report may not be reproduced, except in full, without written approval by EMSL. The above test must not be used by the client to claim product endorsement by NVLAP nor any agency of the United States Government. Laboratory is not responsible for the accuracy of information requested to physically separate and analyze layered samples.

MAY-16-2002 12:19 AM ZUCKERMAN
ID)APEX ENVIRONMENTAL PAGE:007 R=97%
APR-02-2002 12:05PM TEL)3019375701

EMSL Analytical, Inc.
10768 Baltimore Avenue
Beltsville, MD 20705
Phone: (301) 937-5700 Fax: (301) 937-5701

Attn.: Steve Simmons
Apex Environmental, Inc. (MD)
16860 Crabbs Branch Way
Suite 200
Rockville, MD 20855

Tuesday, April 02, 2002

Ref Number: MD021668

POLARIZED LIGHT MICROSCOPY (PLM)

Performed by EPA 600/R-93/116 Method*

Project: 2900 Albermarle Wash, DC

Sample	Location	Appearance	Sample Treatment	ASBESTOS % Type	NON-ASBESTOS % Fibrous	% Non-Fibrous
040102BZCEN 8030(SKIM COAT)	Plaster	White Non-Fibrous Heterogeneous	Teased/Dissolved	None Detected	None Detected	55% Ca Carbonate 45% Other
040102BZCEN 8030(BROWN COAT)	Plaster	Grey Non-Fibrous Heterogeneous	Teased/Dissolved	None Detected	None Detected	50% Quartz 50% Other
040102BZCEN 8031	Duct canvas	Black/Yellow/Beige Fibrous Heterogeneous	Teased/Dissolved	None Detected	35% Cellulose 15% Glass	50% Other
040102BZCEN 8032	Duct mastic	Tan/Black/Silver Fibrous Heterogeneous	Teased/Dissolved	None Detected	30% Glass	70% Other
040102BZCEN 8033	Duct mastic	Tan/Black/Silver Fibrous Heterogeneous	Teased/Dissolved	None Detected	30% Glass	70% Other
040102BZCEN 8034	Roof mastic	Black Fibrous Heterogeneous	Teased/Dissolved	12% Chrysotile	10% Cellulose	78% Other

Comments: For all obviously heterogeneous samples easily separated into subsamples, and for layered samples, each component is analyzed separately. Also, "# of Layers" refers to number of separable subsamples.

* NY samples analyzed by ELAP 198.1 Method.

Russell Meyer
Analyst

Approved Signatory

Disclaimer: PLM has been known to miss asbestos in a small percentage of samples which contain asbestos. Thus negative PLM results cannot be guaranteed. EMSL suggests that samples reported as <1% or none detected be tested with either SEM or TEM. The above test report relates only to the items tested. This report may not be reproduced, except in full, without written approval by EMSL. The above test report not be used by the client to claim product endorsement by NVLAP nor any agency of the United States Government. Laboratory is not responsible for the accuracy of results when requested to physically separate and analyze layered samples.

EMSL Analytical, Inc.
10768 Baltimore Avenue
Beltsville, MD 20705
Phone: (301) 937-5700 Fax: (301) 937-5701

Attn.: Steve Simmons
Apex Environmental, Inc. (MD)
15850 Crabbs Branch Way
Suite 200
Rockville, MD 20855

Tuesday, April 02, 2002

Ref Number: MD021668

POLARIZED LIGHT MICROSCOPY (PLM)

Performed by EPA 600/R-93/116 Method*

Project: 2900 Albermarle Wash, DC

Sample	Location	Appearance	Sample Treatment	ASBESTOS % Type	NON-ASBESTOS % Fibrous	% Non-Fibrous
040102SZCEN B036	Window caulk exterior	Tan/Cream Non-Fibrous Heterogeneous	Teased/Dissolved	None Detected	None Detected	100% Other
040102SZCEN B038	Flex duct joint white	Grey Fibrous Homogeneous	Teased/Dissolved	None Detected	85% Cellulose	15% Other
040102SZCEN B037	Flex duct joint brown	Grey Fibrous Homogeneous	Teased/Dissolved	75% Chrysotile	15% Cellulose	10% Other

Comments: For all obviously heterogeneous samples easily separated into subsamples, and for layered samples, each component is analyzed separately. Also, "# of Layers" refers to number of separable subsamples.

* NY samples analyzed by ELAP 198.1 Method.

Russell Meyer
Analyst

Approved Signatory

Disclaimer: PLM has been known to miss asbestos in a small percentage of samples which contain asbestos. Thus negative PLM results cannot be guaranteed. EMSL suggests that samples reporting as <1% or none detected be tested with either SEM or TEM. The above test report relates only to the items tested. This report may not be reproduced, except in full, without written approval by EMSL. The above test result not be used by the client to claim product endorsement by NVLAP nor any agency of the United States Government. Laboratory is not responsible for the accuracy of results when requested to physically separate and analyze layered samples.

Apex Environmental, Inc.

CHAIN OF CUSTODY/DATA FORM

15850 Crabbs Branch Way
Rockville, MD 20855
(301) 417-0200

Project Name: CHANCERY BUILDING
Client: STONER ZUCKERMAN
Site: 2900 ALBEMARLE
Site Address: 2900 ALBEMARLE WASH D C
Apex Job No.:

Date: 4/1/02
Client Contact:
Client Phone:
Client Address:

Contractor:
Contractor Contact:
Contractor Phone:
Sampling & Analytical Method:
On Site _____ Lab _____

Abbreviations: Fld = background sample; FD = duplicate sample; TRIP = trip blank; RB = rinsate blank; EB = equipment blank; AB = ambient blank; CB = bulk blank; MS = matrix spike; MSD = matrix spike duplicate; SPLIT = split sample

Apex Sample Identification	Apex Container	Location/Description	Sample Type	Date Collected	Time Collected	Preservation Used	Analysis	Number of Containers	Filtered (Y/N)	Total Volume	Flow Rate	Pump #
OH0102-32-CEN-B001		9x9 FLOOR TILE GREEN	FLOOR	1								
B002		BLACK MASTIC										
B003		9x9 FLOOR TILE GREEN										
B004		BLACK MASTIC										
B005		12"x12" CERAMIC TILE										
B006		12"x12" CERAMIC TILE										
B007		DRYWALL										
B008		PLASTER										
B009		WINDOW CAULK										
B010		LINOLEUM GREEN/WHITE TAN										
B011		LINOLEUM MASTIC										
B012		DRYWALL WITH PLASTER										
B013		[illegible]										

PLASTER CEILING TO TWO

SHIPPED VIA:	SHIPPING TICKET #:		PUMP #	ROTAMETER	(#) FLOW RATE (#)
SAMPLES TAKEN BY:					
RELINQUISHED BY: (DATE/TIME) 2:15PM 4-1-02	RECEIVED BY: 4/1/02 2:45				
RELINQUISHED BY: (DATE/TIME)	RECEIVED BY:				
RELINQUISHED BY: (DATE/TIME)	RECEIVED BY:				
RELINQUISHED BY: (DATE/TIME)	RECEIVED BY:				
COMMENTS/SPECIAL INSTRUCTIONS: 24 HR TURNAROUND ATTention SCOTT McALLISTER	ON TIME ON SITE _____ OFF TIME OFF SITE _____ TOTAL BILLABLE HOURS _____ TOTAL BILLABLE SAMPLES (BLANKS + SAMPLES + FIELD SAMPLES) _____		Manifest ID#: _____ Please Sign Chain-of-Custody: Yes No PAHs, Reinforced: OK		

(2)

Apex Environmental, Inc.

CHAIN OF CUSTODY/DATA FORM

15850 Crabbs Branch Way
Rockville, MD 20855
(301) 417-0220

Project Number: Historic Christ Church | Date: 4-1-02 | Consultant:

Client: Shalom Zucker III Inc | Client Contact: | Consultant Contact:

Site: 2900 Albemarle | Client Phone: | Consultant Phone:

Site Address: 2900 Albemarle Wash. DC | Client Address: | Sampling & Analytical Method:

On Site _____ Lab _____

Apex Job No.: | Preservation: P = unpreserved plastic; AG = unpreserved amber glass; SG = Soil sleeves; EC = encore sampler; V = vials; B = bottle; O = other preservation (specify); Filtration: F = field filtered; LF = lab filtered; NF = not filtered

FIELD IDENTIFICATION	APEX NUMBER	LOCATION/DESCRIPTION	SAMPLE TYPE	TIME 24h	TIME 12h	SAMPLING DEPTH	MATRIX	PRESERVATIVE FIELD	PRESERVATIVE FOR CO	TYPE	FILTERED	PUMP #
040102SCON B014		~~Duct Fragment of Lathing~~	Bulk			PLASTER CON'T		Textured				
B015		Textured Plaster										
B016		Tan Cream White Chocolate										
B017		Mastic										
B018		Tk 9 Blue Floor Tile										
B019		Mastic										
B020		~~Plaster Base Coat~~										
B021		~~Mastic~~ 9x9 Floor Tile										
B022		Mastic										
B023		Canvas Duct Covering										
B024		Plaster										
B025		Plaster										
B026		Plaster										

SHIPPED BY:	SHIPPING TICKET #:		PUMP #	INITIALS	(+) FLOW RATE (-)
SHIP, OR DROP BY:					
RELINQUISHED BY: (DATE/TIME) 4-1-02 2:15PM	RECEIVED BY:	4/1/02 2:45			
RELINQUISHED BY: (DATE/TIME)	RECEIVED BY:				
RELINQUISHED BY: (DATE/TIME)	RECEIVED BY:				
RELINQUISHED BY: (DATE/TIME)	RECEIVED BY:				
SHIPMENT SPECIAL INSTRUCTIONS: 24 hr Turnaround ATTENTION Scott McAllister	IN TIME ON SITE: _____ IN TIME OFF SITE: _____ TOTAL BILLABLE HOURS: _____ TOTAL BILLABLE SAMPLES (BLANKS + SAMPLES - VOIDED SAMPLES): _____		Monotempo ID: _____ Phone Rings Consistently: Yes No Filter Readout: OK		

(2)

Apex Environmental, Inc. CHAIN OF CUSTODY/DATA FORM 12850 Oriskany Branch Way Rockville, MD 20850 (301) 417-0200	Industrial Hygienist: Alexandria	Date: 4-1-02	Contractor:
	Client: STUART ROSENTHAL	Client Contact:	Contractor Contact:
	Site: 2900 ALBEMARLE	Client Phone:	Contractor Phone:
	Site Address: 2900 ALBEMARLE WASH DC	Client Address:	Sampling & Analytical Method:
	Apex Job No.:		On Site: ____ Lab: ____

FIELD IDENTIFICATION	APEX NUMBER	LOCATION/EMPLOYEE	SAMPLE TYPE	TIME ON	TIME OFF	DURATION (MINUTES)	LEVEL	PUMP# RELEASE	PUMP# END CC	TEA	FLOW RATE	PUMP #
040102SCON B027		PLASTER	BULK									
B028		PLASTER										
B029		PLASTER										
B030		PLASTER										
B031		DUCT CANVAS										
B032		DUCT MASTIC										
B033		DUCT MASTIC										
B034		ROOF MASTIC										
B035		WINDOW CAULK EXTERIOR										
B036		FLEX DUCT JOINT WHITE										
B037		FLEX DUCT JOINT BROWN										

SHIPPED VIA:	SHIPPING TICKET #:	PUMP #	ROTAMETER	(d) FLOW RATE (A)	
SAMPLES TAKEN BY:					
RELINQUISHED BY: (DATE/TIME) 7:45 PM 4/2	RECEIVED BY: 4/1/02 7:45				
RELINQUISHED BY: (DATE/TIME)	RECEIVED BY:				
RELINQUISHED BY: (DATE/TIME)	RECEIVED BY:				
RELINQUISHED BY: (DATE/TIME)	RECEIVED BY:				
ADDITIONAL INSTRUCTIONS: 24 Hr Turnaround Attention Scott McBride	ON TIME ON SITE: ____ IN TIME OFF SITE: ____ TOTAL BILLABLE HOURS: ____ TOTAL BILLABLE SAMPLES (BLANKS + SAMPLES + VOIDED SAMPLES): ____		Microscope ID: ____ Please Range Check/Filter: Yes No If Yes, Range/Code: OK		

114

GOVERNMENT OF THE DISTRICT OF COLUMBIA
Department of Consumer and Regulatory Affairs

Office of the General Counsel

July 23, 2002

Mr. J. Brendan Herron, Jr.
2901 Ablemarle Street, NW
Washington, D.C. 20008

Dear Mr. Herron:

By its Final Decision, dated June 12, 2002, the Secretary of the District of Columbia directed the Department of Consumer and Regulatory Affairs to provide a written response to your April 22, 2002, letter requesting the following records under the Freedom of Information Act (FOIA):

> [A]ll records held by the Department of Consumer and Regulatory Affairs and all its offices or subdivisions (including without limits, department responsible for building permits and permit enforcement) hereby referred to collectively as "DCRA") pertaining to any and all applications for subdivision, building permits, raze permits and any correspondence relating to any such applications filed for 2900 Ablemarle Street NW and/or 2902 Ablemarle Street NW as well as any other correspondence to or from the DCRA regarding 2900 Ablemarle Street and/or 2902 Ablemarle Street NW, for the period From November 1, 2001, to the present. These record should include (but shall not be limited to) all contracts, drafts, plans, approval sheet, notes, emails, telephone records, memoranda, staff memoranda, and internal and external correspondence, as well as any other papers.

As directed by the Secretary's final decision, DCRA

941 North Capitol Street, N.E., Room 9400, Washington, D.C. 20002
Phone: (202) 442-8475 Fax: (202) 442-9447

conducted the appropriate searches and records responsive to your request have been located. A copy of these records has been made and, as you were advised telephonically, are now available for your pick up. DCRA will not assess any fees for this response.

Should you have any questions, or to schedule an appointment to pick up the records, please contact the undersigned Freedom of Information Officer, Department of Consumer and Regulatory Affairs, 941 North Capitol Street, NE, Suite 2000, Washington, D.C. 20002, telephone (202) 442-4677.

Any challenge to the adequacy of the agency's response must be presented to the Mayor of the District of Columbia, pursuant to the Freedom of Information Act, D.C. Code §2-537 (2001) (Administrative Appeals).

Sincerely,

Robert Henry
Freedom of Information Officer

Copies to: Beverly D. Rivers
Secretary of the District of Columbia

David A. Clark
Director


Teresa D. Lewis
Deputy Director

7/26/02

Received Submission

Appear to be missing
- Site Plan
- Storm Water Management Plan
- Request for Driveway cut
- Survey dated May 18th

116



CELLAR PLAN

Scale: 1/4" = 1'-0"

FINISHED SQUARE FOOTAGE: 1656

CODE ANALYSIS

USE GROUP: R
CONSTRUCTION TYPE:
COMBUSTIBLE WOOD-FRAME & MASONRY
DESIGN STANDARDS:
ONE AND TWO FAMILY DWELLING CODE, NATIONAL BUILDING CODE, NFPA 13D AND ALL APPLICABLE LOCAL CODES

NOTE:
BUILDING SHALL BE FULLY SPRINKLED. SPRINKLER CONTRACTOR TO PROVIDE SHOP DRAWINGS

#2900 ALBEMARLE STREET, NW
#2902 ALBEMARLE ST., NW


© COPYRIGHT © CLAIMED ON ALL OF THE ORIGINAL DETAILS AND INFORMATION ON THIS SHEET. COMMON LAW COPYRIGHT AND ALL OTHER APPLICABLE PROPERTY RIGHTS ARE RESERVED EXCLUSIVELY BY RICHARD TRAHE PYNOYER. REPRODUCTION IN PART OR IN THE FORM OF BUILDING OR RE-BUILDING FROM THESE PLANS WITHOUT THE WRITTEN PERMISSION OF RICHARD TRAHE PYNOYER IS STRICTLY FORBIDDEN.

SPEIGHT ARCHITECTS
COLESPRING PLAZA SUITE 214
1001 SPRING STREET
SILVER SPRING, MD. 20910-4008
PHONE (301) 588-1001

DATE: MARCH 4, 2002
DRAWN
REVISIONS
MARCH 13,2002
MARCH 25,2002

ZUCKERMAN BROTHERS, INC.
TWO WISCONSIN CIRCLE, SUITE 560
CHEVY CHASE, MARYLAND 20815
2902 ALBEMARLE STREET, N.W.
WASHINGTON, D.C. (202) 237-7022

A1



FIRST FLOOR PLAN

Scale: 1/4" = 1'-0"

FINISHED SQUARE FOOTAGE 2,000

SPEIGHT ARCHITECTS
COLESPRING PLAZA SUITE 214
1001 SPRING STREET
SILVER SPRING, MD. 20910-4006
PHONE (301) 588-1001

DATE: MARCH 4, 2002

DRAWN


REVISIONS

MARCH 15, 2002
MARCH 22, 2002

ZUCKERMAN BROTHERS, INC.
TWO WISCONSIN CIRCLE, SUITE 560
CHEVY CHASE, MARYLAND 20815
2902 ALBEMARLE STREET, N.W.
WASHINGTON, D.C. (202) 237-7022

A2

SP 2



SECOND FLOOR PLAN

Scale: 1/4" = 1'-0"

FINISHED SQUARE FOOTAGE = 1,885 SF

SPEIGHT ARCHITECTS
COLESPRING PLAZA SUITE 214
1001 SPRING STREET
SILVER SPRING, MD. 20910-4006
PHONE: (301) 589-1001


DATE: MARCH 4, 2008

REVISIONS:
MARCH 12, 2008
MARCH 17, 2008


ZUCKERMAN BROTHERS, INC.
TWO WISCONSIN CIRCLE, SUITE 560
CHEVY CHASE, MARYLAND 20815
2902 ALBEMARLE STREET, N.W.
WASHINGTON, D.C. (202) 237-7022

A3


A © COPYRIGHT IS CLAIMED ON ALL OF THE DESIGNS, DETAILS AND INFORMATION ON THIS SHEET. COMMON LAW COPYRIGHT AND ALL OTHER APPLICABLE PROPERTY RIGHTS ARE RESERVED EXCLUSIVELY BY RICHARD TRAIB SPEIGHT. REPRODUCTION IN PART OR IN WHOLE OF BUILDINGS OR RE-PRINTING FROM THESE PLANS WITHOUT THE EXPRESS WRITTEN PERMISSION OF RICHARD TRAIB SPEIGHT IS STRICTLY FORBIDDEN.



ROOF TRUSS "B"M
Scale: 1/4"=1'-0"



ROOF TRUSS DIAG. "A"
Scale: 1/4" = 1'-0"




ROOF PLAN
Scale: 1/4" = 1'-0"

A4

ZUCKERMAN BROTHERS, INC.
TWO WISCONSIN CIRCLE, SUITE 560
CHEVY CHASE, MARYLAND 20815
2902 ALBEMARLE STREET, N.W.
WASHINGTON, D.C. (202) 237-7022

SPEIGHT ARCHITECTS
COLESPRING PLAZA SUITE 214
1001 SPRING STREET
SILVER SPRING, MD. 20910-4006
PHONE: (301) 588-1001



FRONT ELEVATION
Scale: 1/4" = 1'-0"

NOTE: HEIGHT OF HOUSE = 22.2'

#2902

A.D. COPYRIGHT © CLAIMED ON ALL OF THE GRAPHIC DETAILS AND INFORMATION ON THE ARCH. CONSULAR COPYRIGHT AND ALL OTHER INTELLECTUAL PROPERTY RIGHTS AS REQUIRED BY LAW. ALL OF THESE RIGHTS RESERVED. THIS DRAWING IS THE EXCLUSIVE PROPERTY OF THE ARCHITECT AND MAY NOT BE USED OR REPRODUCED IN ANY FORM OR MANNER WHATSOEVER WITHOUT THE PRIOR WRITTEN CONSENT OF THE ARCHITECT. UNAUTHORIZED USE OF THIS DRAWING IS STRICTLY FORBIDDEN.

SPEIGHT ARCHITECTS
COLESPRING PLAZA SUITE 214
1001 SPRING STREET
SILVER SPRING, MD. 20910-4006
PHONE: (301) 588-1001

COMMISSION NUMBER

DATE JULY 8, 999

DRAWN

REVISIONS

ZUCKERMAN BROTHERS, INC.
TWO WISCONSIN CIRCLE, SUITE 560
CHEVY CHASE, MARYLAND 20815
2902 ALBEMARLE STREET, N.W.
WASHINGTON, D.C. (202) 237-7022

A5

SH. 5





RIGHT ELEVATION
Scale: 1/4" = 1'-0"

Complies with requirements of [illegible] 4/24/01

#2902

A © COPYRIGHT IS CLAIMED ON ALL OF THE DESIGN, DETAILS AND INFORMATION ON THIS SHEET. COMMON LAW COPYRIGHT AND ALL OTHER APPLICABLE PROPERTY RIGHTS ARE RESERVED EXCLUSIVELY BY SPEIGHT ARCHITECTS. REPRODUCTION IN PART OR IN WHOLE OR RELEASE OF THIS PLAN TO ANY OTHER PARTY WITHOUT THE WRITTEN PERMISSION OF SPEIGHT ARCHITECTS IS STRICTLY FORBIDDEN

SPEIGHT ARCHITECTS
COLESPRING PLAZA SUITE 214
1001 SPRING STREET
SILVER SPRING, MD. 20910-4006
PHONE: (301) 588-1001

COMMISSION NUMBER
DATE JULY 9, 1999
DRAWN
REVISIONS

ZUCKERMAN BROTHERS, INC.
TWO WISCONSIN CIRCLE, SUITE 560
CHEVY CHASE, MARYLAND 20815
2902 ALBEMARLE STREET, N.W.
WASHINGTON, D.C. (202) 237-7022

A6

OF



REAR ELEVATION
Scale: 1/4" = 1'-0"

#2902

A © COPYRIGHT IS CLAIMED ON ALL OF THE DESIGNS, DETAILS AND INFORMATION ON THIS PRINT. COMMON LAW COPYRIGHT AND ALL OTHER APPLICABLE PROPERTY RIGHTS ARE RESERVED EXCLUSIVELY BY RICHARD TRAUB (FIRM#). REPRODUCTION IN PART OR IN WHOLE OF SELLING OR PUBLISHING FROM THIS PLANS WITHOUT THE EXPRESS WRITTEN PERMISSION OF RICHARD TRAUB (FIRM#) IS STRICTLY FORBIDDEN

SPEIGHT ARCHITECTS
COLESPRING PLAZA SUITE 214
1001 SPRING STREET
SILVER SPRING, MD. 20910-4006
PHONE: (301) 588-1001

DATE JULY 13, 1999

ZUCKERMAN BROTHERS, INC.
TWO WISCONSIN CIRCLE, SUITE 560
CHEVY CHASE, MARYLAND 20815
2902 ALBEMARLE STREET, N.W.
WASHINGTON, D.C. (202) 237-7022

A7

LEFT ELEVATION
Scale: 1/4" = 1'-0"

Comply with approval of Preliminary Plan #1-04 4/4/05

#2902

A © COPYRIGHT IS CLAIMED ON ALL OF THE DESIGNS, DETAILS AND INFORMATION ON THIS SHEET. COMMON LAW COPYRIGHT AND ALL OTHER APPLICABLE PROPERTY RIGHTS ARE ASSERTED EXCLUSIVELY BY SPEIGHT, VINK, FERRO ARCHITECTS, P.A. NO PART OF THIS SHEET MAY BE REPRODUCED, STORED IN A RETRIEVAL SYSTEM OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC, MECHANICAL, PHOTOCOPYING, RECORDING OR OTHERWISE, WITHOUT THE PRIOR WRITTEN PERMISSION OF SPEIGHT, VINK, FERRO ARCHITECTS, P.A.

SPEIGHT ARCHITECTS
COLESPRING PLAZA SUITE 214
1001 SPRING STREET
SILVER SPRING, MD. 20910-4006
PHONE: (301) 588-1001

COMMISSION NUMBER


DATE JULY 8, 1999

DRAWN

REVISIONS

ZUCKERMAN BROTHERS, INC.
TWO WISCONSIN CIRCLE SUITE 560
CHEVY CHASE, MARYLAND 20815
2902 ALBEMARLE STREET, N.W.
WASHINGTON, D.C. (202) 237-7022

A8



FRONT ELEVATION


Scale: 1/4" = 1'-0"

SPEIGHT ARCHITECTS
COLESPRING PLAZA SUITE 214
1001 SPRING STREET
SILVER SPRING, MD. 20910-4006
PHONE (301) 588-1001

DATE: MARCH 29, 2002

ZUCKERMAN BROTHERS, INC.
TWO WISCONSIN CIRCLE, SUITE 560
CHEVY CHASE, MARYLAND 20815
2900 ALBEMARLE STREET, N.W.
WASHINGTON, D.C. (202) 237-7022

A5.1



RIGHT ELEVATION
Scale: 1/4" = 1'-0"

#2900

A © COPYRIGHT IS CLAIMED ON ALL OF THE DESIGN, DETAILS AND INFORMATION ON THIS SHEET. ALL SUCH COPYRIGHT AND ALL OTHER AND LEGAL PROPERTY RIGHTS ARE RESERVED. REPRODUCTION OF THIS SHEET OR ANY PART THEREOF BY ANY MEANS WHATSOEVER IS PROHIBITED, OR BUILDING OR CONSTRUCTION FROM SUCH PLANS WITHOUT THE EXPRESS WRITTEN PERMISSION OF RICHARD SPEIGHT IS STRICTLY FORBIDDEN.

SPEIGHT ARCHITECTS
COLESPRING PLAZA SUITE 214
1001 SPRING STREET
SILVER SPRING, MD. 20910-4006
PHONE: (301) 588-1001

DATE MARCH 29, 2002
DRAWN
REVISIONS
APRIL 2 2002

ZUCKERMAN BROTHERS, INC.
TWO WISCONSIN CIRCLE, SUITE 560
CHEVY CHASE, MARYLAND 20815
2900 ADEMARLE STREET, N.W.
WASHINGTON, D.C. (202) 237-7022

A6



REAR ELEVATION
Scale: 1/4" = 1'-0"

#2900

A © COPYRIGHT IS CLAIMED ON ALL OF THE ORIGINAL DETAILS AND INFORMATION OF THE WORK. COMMON LAW COPYRIGHT AND ALL other APPLICABLE PROPERTY RIGHTS ARE RESERVED EXCLUSIVELY BY RICHARD TRAIB SPEIGHT. REPRODUCTION IN PRINT OR IN WHOLE OR IN PART OR RELEASING FROM HAND IS NOT WITHOUT THE EXPRESS WRITTEN PERMISSION OF RICHARD TRAIB SPEIGHT IS STRICTLY FORBIDDEN.

SPEIGHT ARCHITECTS
COLESPRING PLAZA SUITE 214
1001 SPRING STREET
SILVER SPRING, MD. 20910-4006
PHONE: (301) 588-1001

COMMISSION NUMBER

DATE: MARCH 29, 2003
DRAWN
REVISIONS
APRIL 2 2003

ZUCKERMAN BROTHERS, INC.
TWO WISCONSIN CIRCLE SUITE 560
CHEVY CHASE, MARYLAND 20815
2900 ALBEMARLE STREET, N.W.
WASHINGTON, D.C. (202) 237-7022

A7A



LEFT ELEVATION
Scale: 1/4" = 1'-0"

#2900

A © COPYRIGHT IS CLAIMED ON ALL OF THE DRAWINGS, DETAILS AND SPECIFICATIONS OF THE WORK. COMMON LAW COPYRIGHT AND ALL OTHER APPLICABLE PROPERTY RIGHTS ARE RESERVED, INCLUDING, BY RECORD, THOSE RIGHTS IN REPRODUCTION IN PART OR IN WHOLE OR BUILDING OR REBUILDING FROM THESE PLANS WITHOUT THE EXPRESS WRITTEN PERMISSION OF RICHARD TRAIB. RIGHT IS STRICTLY FORBIDDEN.

SPEIGHT ARCHITECTS
COLESPRING PLAZA, SUITE 214
1001 SPRING STREET
SILVER SPRING, MD 20910-4006
PHONE: (301) 588-1001

DATE: MARCH 29, 2003
DRAWN:
REVISIONS:

ZUCKERMAN BROTHERS, INC.
TWO WISCONSIN CIRCLE, SUITE 560
CHEVY CHASE, MARYLAND 20815
2900 ALBEMARLE STREET, N.W.
WASHINGTON, D.C. (202) 237-7022

A8



FRONT ELEVATION
Scale: 1/4" = 1'-0"

NOTE: HEIGHT OF HOUSE = 22.2'

#2902

A © COPYRIGHT IS CLAIMED ON ALL OF THE ORIGINAL DETAILS AND INFORMATION ON THIS SHEET. COMMON LAW COPYRIGHT AND ALL OTHER LEGAL PROPERTY RIGHTS ARE RESERVED. REPRODUCTION OF THIS SHEET IN WHOLE OR IN PART BY ANY MEANS WHATSOEVER IS PROHIBITED EXCEPT BY WRITTEN PERMISSION OF SPEIGHT ARCHITECTS. ANY REPRODUCTION OF THIS SHEET WITHOUT THE EXPRESS WRITTEN PERMISSION OF SPEIGHT ARCHITECTS IS STRICTLY FORBIDDEN.


SPEIGHT ARCHITECTS
COLESPRING PLAZA SUITE 214
1000 SPRING STREET
SILVER SPRING, MD 20910-4006
PHONE: (301) 588-1001


COMMISSION NUMBER
DATE JULY 2, 1999
DRAWN
REVISIONS

ZUCKERMAN BROTHERS, INC.
TWO WISCONSIN CIRCLE, SUITE 560
CHEVY CHASE, MARYLAND 20815
2902 ALBEMARLE STREET, N.W.
WASHINGTON, D.C. (202) 237-7022

A5

DR 5





RIGHT ELEVATION
Scale: 1/4" = 1'-0"

Complies with requirements of [illegible]
[illegible] 4/24/00

#2902

A © COPYRIGHT IS CLAIMED ON ALL OF THE DESIGNS, DETAILS AND INFORMATION ON THIS SHEET. COMMON LAW COPYRIGHT AND ALL OTHER APPLICABLE PROPERTY RIGHTS ARE RESERVED HEREIN. ALL RIGHTS HAVE BEEN EXPRESSLY RESERVED. NO PART OF THIS SHEET OR ANY REPRODUCTION OF A PART OF IT MAY BE USED OR REPRODUCED BY ANY PERSON OR ENTITY FOR ANY PURPOSE WHATSOEVER WITHOUT THE EXPRESS WRITTEN CONSENT OF RICHARD TRAIN. UNAUTHORIZED USE OF THIS SHEET IS STRICTLY FORBIDDEN.

CONSTRUCTION NUMBER

SPEIGHT ARCHITECTS
COLESPRING PLAZA, SUITE 214
10101 COLESPRING STREET
SILVER SPRING, MD. 20910-4006
PHONE: (301) 588-1001

DATE JULY 13, 999
DRAWN
REVISIONS

ZUCKERMAN BROTHERS, INC.
TWO WISCONSIN CIRCLE, SUITE 560
CHEVY CHASE, MARYLAND 20815
2902 ALBEMARLE STREET, N.W.
WASHINGTON, D.C. (202) 237-7022

A6

OF 6



REAR ELEVATION
Scale: 1/4" = 1'-0"

#2902

A © COPYRIGHT IS CLAIMED ON ALL OF THE DESIGN, DETAILS AND INFORMATION OF THIS SHEET. COMMERCIAL COPYRIGHT AND ALL OTHER APPLICABLE PROPERTY RIGHTS ARE RESERVED EXCLUSIVELY BY ARCHITECTS. THIS DRAWING, INFORMATION OR ANY PART OF IT MAY NOT BE USED OR REPRODUCED IN ANY MANNER WITHOUT THE PRIOR WRITTEN PERMISSION OF ARCHITECTS. ANY UNAUTHORIZED USE OR REPRODUCTION WITHOUT SUCH PERMISSION IS STRICTLY FORBIDDEN.

SPEIGHT ARCHITECTS
COLESPRING PLAZA SUITE 214
1001 SPRING STREET
SILVER SPRING, MD. 20910-4006
PHONE: (301) 588-1001

CONSTRUCTION NUMBER

DATE JULY 8, 199

DRAWN

REVISIONS

ZUCKERMAN BROTHERS, INC.
TWO WISCONSIN CIRCLE, SUITE 560
CHEVY CHASE, MARYLAND 20815
2902 ALBEMARLE STREET, N.W.
WASHINGTON, D.C. (202) 237-7022

A7

OF 7

LEFT ELEVATION
Scale: 1/4" = 1'-0"

Complies with requirements of [illegible] 4/4/02

#2902

ALL COPYRIGHT IS CLAIMED ON ALL OF THE DRAWINGS, DETAILS AND SPECIFICATIONS ON THIS SHEET. COMMON LAW COPYRIGHT AND ALL OTHER RIGHTS, INCLUDING PUBLICATION AND/OR EXCLUSIVE USE, ARE RESERVED BY SPEIGHT ARCHITECTS. NONE OF THE DRAWINGS, DETAILS AND SPECIFICATIONS RELATED TO THIS SHEET MAY BE USED OR REPRODUCED IN ANY FORM WITHOUT THE WRITTEN PERMISSION OF SPEIGHT ARCHITECTS.

SPEIGHT ARCHITECTS
COLESPRING PLAZA SUITE 214
1001 SPRING STREET
SILVER SPRING, MD. 20910-4006
PHONE: (301) 588-1001

DATE JULY 9, 1999

ZUCKERMAN BROTHERS, INC.
TWO WISCONSIN CIRCLE, SUITE 580
CHEVY CHASE, MARYLAND 20815
2902 ALBEMARLE STREET, N.W.
WASHINGTON, D.C. (202) 237-7022

A8

STRUCTURAL NOTES

LIVE LOADS ROOF 30 PSF

[illegible]


GENERAL NOTES

1. CODES ALL WORK MUST CONFROM TO APPLICABLE CODES.

[illegible]

ABOVE NOTES APPLY UNLESS OTHERWISE SPECIFIED ON DRAWINGS.

[illegible]




TYPICAL WALL SECTION
SCALE 1/2" = 1'-0"

SPEIGHT ARCHITECTS
COLESPRING PLAZA SUITE 214
1001 SPRING STREET
SILVER SPRING, MD. 20910-4008
PHONE: 588-1002

DATE MARCH 22, 2002


ZUCKERMAN BROTHERS, INC.
TWO WISCONCIN CIR., SUITE 560
CHEVY CHASE, MARYLAND 20815
2902 ALBEMARLE STREET, N.W.
WASHINGTON, D.C. (202) 237-7022

A9




TYPICAL SECTION


Scale: 1 1/2"=1'-0"



TYPICAL STAIR SECTION

Scale: 1 1/2"=1'-0"






WINDOW SCHEDULE NOTE: WINDOW DIMENSIONS ARE NOMINAL AND SIZES ARE AS SPECIFIED ON THE FLOOR PLANS. INSTALL AS PER MANUFACTURER SPECS.

DOOR SCHEDULE NOTE: DOOR MEMBER SIZES ARE 1 3/8" UNLESS SPECIFIED OTHERWISE ON PLANS. DOOR WIDTHS ARE AS SPECIFIED ON FLOOR PLANS.



FAMILY ROOM
FIREPLACE PLAN

Scale: 1/4"=1'-0"




RECREATION ROOM
FIREPLACE PLAN

Scale: 1/4"=1'-0"



FAMILY ROOM
FIREPLACE ELEVATION


Scale: 1/4"=1'-0"



LIVING ROOM
FIREPLACE ELEVATION

Scale: 1/4"=1'-0"

SUPERIOR FIREPLACE CO. MODEL RD-4300A
PHONE: (800) 854-0257



PREFABRICATED WOOD BURNING FIREPLACE DETAILS

NOTE: INSTALL AS PER MANUFACTURERS SPECIFICATIONS

CONSTRUCTION DETAILS

© COPYRIGHT © CLAUDIO OR ALL OF THE DESIGN DETAILS AND INFORMATION ON THIS SHEET, COMMERCIAL LAW COPYRIGHT AND ALL OTHER APPLICABLE PROPERTY RIGHTS ARE RESERVED EXCLUSIVELY BY CLAUDIO. THESE DRAWINGS OR SPECIFICATIONS OR ANY COPY OR ANY PART OF THEM, OR ANY OF THE DESIGNS SHOWN THEREIN, MAY NOT BE USED BY ANY PERSON OR ENTITY IN ANY WAY OR IN ANY OF BUILDING OR REPRODUCED FROM THEM IN ANY MANNER WHATSOEVER WITHOUT THE PRIOR WRITTEN PERMISSION OF CLAUDIO. ALL RIGHTS RESERVED. TRADE SECRET INFORMATION IS STRICTLY PROHIBITED.

SPEIGHT ARCHITECTS
COLESPRING PLAZA SUITE 214
1001 SPRING STREET
SILVER SPRING, MD. 20910-4006
PHONE: (301) 588-1001

DATE: MARCH 22, 2000

DRAWN: R. T. S.

REVISIONS:

ZUCKERMAN BROTHERS, INC.
TWO WISCONSIN CIRCLE, SUITE 560
CHEVY CHASE, MARYLAND 20815
2902 ALBEMARLE STREET, N.W.
WASHINGTON, D. C. (202) 237-7022

A10

FOOTING PLAN

Scale: 1/4" = 1'-0"


SPEIGHT ARCHITECTS
COLESPRING PLAZA SUITE 214
1001 SPRING STREET
SILVER SPRING, MD. 20910-4006
PHONE: (301) 588-1001

DATE: MARCH 4, 2003
DRAWN:
REVISIONS:
MARCH 20, 2003

ZUCKERMAN BROTHERS, INC.
TWO WISCONSIN CIRCLE, SUITE 560
CHEVY CHASE, MARYLAND 20815
2902 ALBEMARLE STREET, N.W.
WASHINGTON, D.C. (202) 237-7022

S1

A © COPYRIGHT IS CLAIMED ON ALL OF THE DESIGNS, DETAILS AND INFORMATION OF THIS SHEET. COMMON LAW COPYRIGHT AND ALL OTHER APPLICABLE PROPERTY RIGHTS ARE RESERVED EXCLUSIVELY BY RICHARD TRAVIS SPEIGHT. NO PART OF THIS SHEET OR THE IDEAS AND CONSTRUCTION IN IT MAY BE USED OR MADE AVAILABLE FOR USE BY ANY PERSON OR ENTITY FOR ANY PURPOSE WITHOUT THE EXPRESS WRITTEN PERMISSION OF RICHARD TRAVIS SPEIGHT IS STRICTLY FORBIDDEN.



FIRST FLOOR DECK

Scale: 1/4" = 1'-0"

NOTE: ALL STRUCTURAL HEADERS ARE 2-2 X 12 UNLESS NOTED OTHERWISE.

NOTE: WATER CLOSET PLUMBING ACCESS HOLE SHALL BE 4 1/2" DIAMETER, 12 1/2" OFF OF ROUGH WALL FRAMING AND CENTERED ON WATER CLOSET. FIELD VERIFY.

NOTE: TUB PLUMBING ACCESS HOLE SHALL BE 10" X 10" SQUARE, FLUSH WITH ROUGH WALL FRAMING AND CENTERED ON THE TUB. FIELD VERIFY.

NOTE: 4" DIAMETER RECESSED LIGHT FIXTURE REQUIRES MINIMUM 4" FROM THE CENTERLINE OF THE FIXTURE TO THE CLOSEST SIDE OF THE FLOOR JOIST WITH A TOTAL CLEAR OPENING OF 9" BETWEEN EDGES OF JOIST.

NOTE: 6" DIAMETER RECESSED LIGHT FIXTURE REQUIRES MINIMUM 5 1/2" FROM THE CENTERLINE OF THE FIXTURE TO THE CLOSEST SIDE OF THE FLOOR JOIST WITH A TOTAL CLEAR OPENING OF 12" BETWEEN EDGES OF JOIST.

NOTED FIRE-LIFE-SAFETY

By Fire Protection Division

A © COPYRIGHT IS CLAIMED ON ALL OF THE DESIGNS, DETAILS AND INFORMATION ON THIS SHEET. COMMON LAW COPYRIGHT AND ALL OTHER APPLICABLE PROPERTY RIGHTS ARE RESERVED EXCLUSIVELY BY RICHARD TRAVIS SPEIGHT. REPRODUCTION IN PART OR IN WHOLE OR BUILDING OR RE-BUILDING FROM THESE PLANS WITHOUT THE EXPRESS WRITTEN PERMISSION OF RICHARD TRAVIS SPEIGHT IS STRICTLY FORBIDDEN.

COMMISSION NUMBER

SPEIGHT ARCHITECTS
COLESPRING PLAZA SUITE 214
1001 SPRING STREET
SILVER SPRING, MD. 20910-4006
PHONE: (301) 588-1001

DATE: MARCH 4, 2002
DRAWN
REVISIONS
MARCH 22, 2002

ZUCKERMAN BROTHERS, INC.
TWO WISCONSIN CIRCLE, SUITE 560
CHEVY CHASE, MARYLAND 20815
2902 ALBEMARLE STREET, N.W.
WASHINGTON, D.C. (202) 237-7022

S2

OF 12

SECOND FLOOR DECK

Scale: 1/4" = 1'-0"

NOTE: ALL STRUCTURAL HEADERS ARE 2-2 X 12 UNLESS NOTED OTHERWISE.

NOTE: WATER CLOSET PLUMBING ACCESS HOLE SHALL BE A 12" DIAMETER OR 12" X 12" SQUARE OPENING IN THE WALL BEHIND THE WATER CLOSET. FIELD VERIFY.

NOTE: TUB PLUMBING ACCESS HOLE SHALL BE 12" X 12" SQUARE, PLUMB WITH ADJACENT WALL FRAMING AND CENTERED OFF THE TUB. FIELD VERIFY.

NOTE: 4" DIAMETER RECESSED LIGHT FIXTURE RECESSED MINIMUM 6 1/2" FROM THE CENTERLINE OF THE FIXTURE TO THE CLOSEST SIDE OF THE FLOOR JOIST, WITH A TOTAL CLEAR OPENING OF 5" BETWEEN SIDES OF JOIST.

NOTE: 4" DIAMETER RECESSED LIGHT FIXTURE RECESSED MINIMUM 6 1/2" FROM THE CENTERLINE OF THE FIXTURE TO THE CLOSEST SIDE OF THE FLOOR JOIST, WITH A TOTAL CLEAR OPENING OF 5" BETWEEN SIDES OF JOIST.

NOTED FOR LIFE-SAFETY

A © COPYRIGHT IS CLAIMED ON ALL OF THE DESIGNS, DETAILS AND INFORMATION ON THIS SHEET. COMMON LAW COPYRIGHT AND ALL OTHER APPLICABLE PROPERTY RIGHTS ARE RESERVED EXCLUSIVELY BY RICHARD TRAHE BRIGHT. REPRODUCTION IN PART OR IN WHOLE OF BUILDING OR BUILDING FROM THESE PLANS WITHOUT THE EXPRESS WRITTEN PERMISSION OF RICHARD TRAHE BRIGHT IS STRICTLY FORBIDDEN.

SPEIGHT ARCHITECTS
COLESPRING PLAZA SUITE 214
1001 SPRING STREET
SILVER SPRING, MD. 20910-4006
PHONE: (301) 588-1001

COMMISSION NUMBER

DATE: MARCH 6, 2009

DRAWN:


REVISIONS:

MARCH 23, 2009


ZUCKERMAN BROTHERS, INC.
TWO WISCONSIN CIRCLE, SUITE 560
CHEVY CHASE, MARYLAND 20815
2002 ALBEMARLE STREET, N.W.
WASHINGTON, D.C. (202) 237-7022

S3


15




ROOF TRUSS "B"M
Scale: 1/4"=1'-0"



ROOF TRUSS DIAG. "A"
Scale: 1/4" = 1'-0"



ROOF TRUSS LAYOUT and
ROOF PLAN
Scale: 1/4" = 1'-0"



ROOF TRUSS DIAG. "C"
Scale: 1/4"=1'-0"


ZUCKERMAN BROTHERS, INC.
TWO WISCONSIN CIRCLE, SUITE 560
CHEVY CHASE, MARYLAND 20815
2902 ALBEMARLE STREET, N.W.
WASHINGTON. D.C. (202) 237-7022

SPEIGHT ARCHITECTS
COLESPRING PLAZA SUITE 214
1001 SPRING STREET
SILVER SPRING, MD. 20910-4006
PHONE: (301) 588-1001

S4

ELECTRIC LEGEND

	110 DUPLEX OUTLET		WALL WASHER		TWO WAY SWITCH		DWL FLOOD LIGHT
	220 VOLT OUTLET		CEILING FIXTURE		THREE WAY SWITCH		TV OUTLET
	WEATHER PROOF GROUND FAULT OUTLET		PULL CHAIN FIXTURE		FOUR WAY SWITCH		TELEPHONE OUTLET
	WEATHER PROOF GROUND FAULT OUTLET		RECESSED FIXTURE		DIMMER SWITCH		18W FLUORESCENT LIGHT
	110 DUPLEX OUTLET W/ SPECIAL PURPOSE		RECESSED LIGHT W/ SHADE		DIMMER 3 WAY SWITCH		RECESSED LIGHT
	DEDICATED OUTLET FOR SWITCH		RECESSED LIGHT W/ SPECIAL REFLECTOR		DIMMER 4 WAY SWITCH		TRACK LIGHT
	DEDICATED OUTLET FOR GARAGE DOOR OPENER		RECESSED FAN				SMOKE DETECTOR



CELLAR ELECTRICAL PLAN

Scale: 1/4" = 1'-0"

ELECTRICAL NOTES

1. ALL WORK SHALL BE DONE IN ACCORDANCE WITH THE NATIONAL ELECTRICAL CODE AND APPLICABLE DC REGULATIONS
2. SUBCONTRACTOR SHALL ACQUIRE ALL NECESSARY PERMITS, INSPECTIONS, ETC. INSPECTIONS WILL BE CALLED FOR ON A DAILY BASIS.
3. SUBCONTRACTOR WILL COORDINATE SERVICE ENTRANCE INSTALLATIONS AND CONNECTIONS WITH THE SERVICE UTILITY.
4. ALL ELECTRICAL MOTORS FOR PLUMBING AND HVAC EQUIPMENT SHALL BE PROVIDED BY THE MECHANICAL TRADES.
5. ALL INTERIOR WIRING SHALL BE NON-METALLIC SHEATHED CABLE, TYPE NM OR SERVICE ENTRANCE CABLE TYPE SE, ALL DIRECT BURIAL WORK AROUND WIRING SHALL BE CABLE TYPE UF.
6. EVERY PIECE IN PULL BOXES AND PANEL CABINETS AND BRANCH CIRCUITS IN OUTLET BOXES AND PULL BOXES HAVING MORE THAN ONE CIRCUIT SHALL BE TAGGED TO SHOW THE NAME OR NUMBER OF THE CIRCUIT.
7. ALL LIGHTING FIXTURES SHALL BE LISTED BY UNDERWRITERS LABORATORIES, INC. OR ELECTRICAL TESTING LABORATORIES. ALL ACCESSORY EQUIPMENT SUCH AS BALLASTS, STARTERS, SOCKETS, AND LAMPHOLDERS SHALL BE LISTED BY UNDERWRITERS LABORATORY, INC. OR ELECTRICAL TESTING LABORATORIES.
8. INCANDESCENT LIGHTING FIXTURES SHALL BE PROVIDED WITH THE PROPER TYPE LAMP. ALL INCANDESCENT LAMPS SHALL BE 130 VOLT, FROSTED AND BE GENERAL ELECTRIC, WESTINGHOUSE, PHILLIPS OR SYLVANIA. RATED VOLTAGE OF INCANDESCENT LAMPS SHALL BE 120 VOLTS.
9. FLUORESCENT LIGHTING FIXTURES SHALL BE PROVIDED WITH THE PROPER TYPE LAMP WITH THE CORRECT SPECIFIED BALLASTS. ALL FLUORESCENT LAMPS SHALL BE SYLVO START AND BE GENERAL ELECTRIC, WESTINGHOUSE, PHILLIPS OR SYLVANIA.
10. ALL DEVICES SHALL BE INSTALLED FLUSH AND LEVEL, AND SHALL HAVE COVER PLATES FITTED TIGHTLY TO THE MOUNTING SURFACES. THE FLOOR BOXES, COVERS, AND TRIM SHALL BE ADJUSTED TO SET THE FINISH FLOOR MATERIAL.

A © COPYRIGHT IS CLAIMED ON ALL OF THE DESIGNS, DETAILS AND INFORMATION ON THIS SHEET. COMMON LAW COPYRIGHT AND ALL OTHER APPLICABLE PROPERTY RIGHTS ARE RESERVED EXCLUSIVELY BY RICHARD TRAHE ARCHITECT. REPRODUCTION IN PART OR IN WHOLE OR BUILDING OF RE-BUILDING FROM THESE PLANS WITHOUT THE EXPRESS WRITTEN PERMISSION OF RICHARD TRAHE ARCHITECT IS STRICTLY FORBIDDEN.

CONSTRUCTION DOCUMENTS

SPEIGHT ARCHITECTS
COLESPRING PLAZA SUITE 214
1001 SPRING STREET
SILVER SPRING, MD. 20910-4006
PHONE: (301) 588-1001

DATE: MARCH 4, 2008
DRAWN
REVISIONS
MARCH 12, 2008
MARCH 19, 2008

ZUCKERMAN BROTHERS, INC.
TWO WISCONSIN CIRCLE, SUITE 560
CHEVY CHASE, MARYLAND 20815
2902 ALBEMARLE STREET, N.W.
WASHINGTON, D.C. (202) 237-7022

E1

ELECTRICAL
FIRST FLOOR PLAN

Scale: 1/4" = 1'-0"

A © COPYRIGHT IS CLAIMED ON ALL OF THE DRAWING DETAILS AND INFORMATION ON THIS SHEET. COMMON LAW COPYRIGHT AND ALL OTHER APPLICABLE PROPERTY RIGHTS ARE RESERVED EXCLUSIVELY BY RICHARD TRAHE BYRNES. REPRODUCTION IN PART OR IN WHOLE OF BUILDING OR RE-USE FROM THESE PLANS WITHOUT THE EXPRESS WRITTEN PERMISSION OF RICHARD TRAHE BYRNES IS STRICTLY FORBIDDEN.

SPEIGHT ARCHITECTS
COLESPRING PLAZA SUITE 214
1001 SPRING STREET
SILVER SPRING, MD 20910-4006
PHONE (301) 588-1001

DATE MARCH 4, 2008
DRAWN
REVISIONS
MARCH 12 2008

ZUCKERMAN BROTHERS, INC.
TWO WISCONSIN CIRCLE, SUITE 560
CHEVY CHASE, MARYLAND 20815
2902 ALBEMARLE STREET, N.W.
WASHINGTON, D.C. (202) 237-7022

E2

ELECTRICAL
SECOND FLOOR PLAN

Scale: 1/4" = 1'-0"

NOTED FIRE/LIFE-SAFETY

A © COPYRIGHT IS CLAIMED ON ALL OF THE DRAWING DETAILS AND INFORMATION ON THIS SHEET. COMMON LAW COPYRIGHT AND ALL OTHER INTELLECTUAL PROPERTY RIGHTS ARE RESERVED EXCLUSIVELY BY RICHARD TRAHE SPEIGHT. REPRODUCTION IN PART OR IN WHOLE OF ANY PART OF THE DRAWING FROM THESE PLANS WITHOUT THE EXPRESS WRITTEN PERMISSION OF RICHARD TRAHE SPEIGHT IS STRICTLY FORBIDDEN.

SPEIGHT ARCHITECTS
COLESPRING PLAZA SUITE 214
1001 SPRING STREET
SILVER SPRING, MD. 20910-4006
PHONE: (301) 588-1001

DATE MARCH 4, 2008
DRAWN
REVISIONS
MARCH 25 2008
MARCH 31 2008

ZUCKERMAN BROTHERS, INC.
TWO WISCONSIN CIRCLE, SUITE 560
CHEVY CHASE, MARYLAND 20815
2302 ADERMARLE STREET, N.W.
WASHINGTON, D.C. (202) 237-7022

E3

17

CELLAR PLAN

Scale: 1/4" = 1'-0"

© COPYRIGHT © CLAIMED ON ALL OF THE DESIGNS, DETAILS AND INFORMATION ON THIS SHEET. COMMON LAW COPYRIGHT AND ALL OTHER APPLICABLE PROPERTY RIGHTS ARE RESERVED EXCLUSIVELY BY SPEIGHT ARCHITECTS. REPRODUCTION IN PART OR IN WHOLE OR BUILDING OR REBUILDING FROM THESE PLANS WITHOUT THE EXPRESS WRITTEN CONSENT OF SPEIGHT ARCHITECTS IS STRICTLY FORBIDDEN.

SPEIGHT ARCHITECTS
COLESPRING PLAZA SUITE 214
1001 SPRING STREET
SILVER SPRING, MD. 20910-4006
PHONE: (301) 588-1001

DATE: MARCH 4, 2008

REVISIONS:
MARCH 12, 2008
MARCH 25, 2008

ZUCKERMAN BROTHERS, INC.
TWO WISCONSIN CIRCLE, SUITE 560
CHEVY CHASE, MARYLAND 20815
2902 ALBEMARLE STREET, N.W.
WASHINGTON, D.C. (202) 237-7022

M1

FIRST FLOOR PLAN

Scale: 1/4" = 1'-0"


SPEIGHT ARCHITECTS
COLESPRING PLAZA SUITE 214
1001 SPRING STREET
SILVER SPRING, MD 20910-4006
PHONE (301) 585-1001

DATE MARCH 4, 2002
DRAWN
REVISIONS

ZUCKERMAN BROTHERS, INC.
TWO WISCONSIN CIRCLE, SUITE 560
CHEVY CHASE, MARYLAND 20815
2902 ALBEMARLE STREET, N.W.
WASHINGTON, D.C. (202) 237-7022

M2

A © COPYRIGHT IS CLAIMED ON ALL OF THE DESIGNS, DETAILS AND INFORMATION ON THE DRAWINGS, CHANGES AND DEVELOPMENT AND ALL OTHER APPLICABLE PROPERTY RIGHTS ARE RESERVED EXCLUSIVELY TO SPEIGHT ARCHITECTS. NO PART OF THESE DRAWINGS SHALL BE REPRODUCED IN ANY FORM OR IN WHOLE OR IN PART BY ANY MEANS WHATSOEVER WITHOUT THE PRIOR WRITTEN PERMISSION OF SPEIGHT ARCHITECTS. THESE PLANS WERE PREPARED BY SPEIGHT ARCHITECTS AND ARE THE PROPERTY OF SPEIGHT ARCHITECTS



SECOND FLOOR PLAN

Scale: 1/4" = 1'-0"

SPEIGHT ARCHITECTS
COLESPRING PLAZA SUITE 214
1001 SPRING STREET
SILVER SPRING, MD. 20910-4006
PHONE: (301) 588-1001

COMMISSION NUMBER

DATE: MARCH 4, 2002

DRAWN

REVISIONS

MARCH 18, 2002


ZUCKERMAN BROTHERS, INC.
TWO WISCONSIN CIRCLE, SUITE 560
CHEVY CHASE, MARYLAND 20815
2602 ALBEMARLE STREET, N.W.
WASHINGTON, D.C. (202) 237-7022

M3

OF 10

A © COPYRIGHT IS CLAIMED ON ALL OF THE ORIGINAL DETAILS AND INFORMATION ON THIS SHEET. COMMON LAW COPYRIGHT AND ALL OTHER APPLICABLE PROPERTY RIGHTS ARE RESERVED EXCLUSIVELY BY RICHARD TRAHAN BUILDER. REPRODUCTION IN ANY FORM OR WHOLE OR IN PART OF BUILDING FROM SAME PLANS WITHOUT THE WRITTEN PERMISSION OF RICHARD TRAHAN BUILDER IS STRICTLY FORBIDDEN.

Waste & Vent Riser




Richard Brothers Quality Plumbing, Inc.
DC License # 70001199

	DFU	WSFU
Basement		
Bath Group (water closet, lav, tub)	7	3.63
DC Hose Bibb (1/2 inch)		4.00
First Floor		
Powder room (water closet, lav)	4	2.63
Kitchen (sink, dishwasher)	3	2.63
Laundry room (sink, washer box)	3	3.40
Second Floor		
Master Bthroom (water closet, 2 lav, tub)	8	5.03
Bedroom Bath (tub, toilet, lav)	7	3.63
Bedroom Bath (tub, toilet, lav)	7	3.63
	36	30.00
Total Drainage Fixture Units	36	
Total Water Supply Fixture Units	30.0	

Average daily flow would depend on the number of people living in house.


Sewer Main 4 Inch PVC
Water Main 1 Inch L Copper tubing

Water Riser (L Copper)



2-PSI C.S.S.T. Tubing (Trac Pipe) Gas Riser

Total BTU - 305,000
Longest Run - 65'
Meter to Manifold - 25'



A © COPYRIGHT IS CLAIMED ON ALL OF THE ORIGINAL DETAILS AND INFORMATION ON THIS SHEET. TO WHICH LAW COPYRIGHT AND ALL OTHER APPLICABLE PROPERTY RIGHTS ARE RESERVED EXCLUSIVELY BY RICHARD TRAHE SPEIGHT. REPRODUCTION IN PART OR IN WHOLE OF INLAND OR BUILDING FROM THESE PLANS WITHOUT THE EXPRESS WRITTEN CONSENT OF RICHARD TRAHE SPEIGHT IS STRICTLY FORBIDDEN.

SPEIGHT ARCHITECTS
COLESPRING PLAZA, SUITE 214
1020 COLESVILLE ROAD
SILVER SPRING, MD 20910-4006
PHONE: (301) 588-1001

CONSTRUCTION NUMBER

DATE MARCH 4, 2002

DRAWN

REVISIONS

MARCH 22, 2002

ZUCKERMAN BROTHERS, INC.
TWO WISCONSIN CIRCLE, SUITE 560
CHEVY CHASE, MARYLAND 20815
2902 ALBEMARLE STREET, N.W.
WASHINGTON, D.C. (202) 237-7022

P1

SHT 21




FRONT ELEVATION
SCALE: 1/4"=1'-0"



SIDE ELEVATION
SCALE: 1/4"=1'-0"





STAIR SECTION
SCALE: 1/4"=1'-0"




RETAINING WALL SCHEDULE													
WALL	A	B	C	D	E	F	G	H	I	J	K	L	M
1	2'-0"	2'-0"	1'-0"	2'-0"	2'-0"	1'-0"	-	[illegible]	[illegible]	-	-	-	-
2	2'-0"	2'-0"	1'-0"	2'-0"	2'-0"	1'-0"	-	[illegible]	[illegible]	-	-	-	-
3	2'-0"	2'-0"	1'-0"	2'-0"	2'-0"	1'-0"	-	[illegible]	[illegible]	-	-	-	-
4	2'-0"	2'-0"	1'-0"	2'-0"	2'-0"	1'-0"	-	[illegible]	[illegible]	-	-	-	-
5	2'-0"	2'-0"	1'-0"	2'-0"	2'-0"	1'-0"	-	[illegible]	[illegible]	-	-	-	-
6	2'-0"	2'-0"	1'-0"	2'-0"	2'-0"	1'-0"	-	[illegible]	[illegible]	-	-	-	-
7	2'-0"	2'-0"	1'-0"	2'-0"	2'-0"	1'-0"	-	[illegible]	[illegible]	-	-	-	-
8	2'-0"	2'-0"	1'-0"	2'-0"	2'-0"	1'-0"	-	[illegible]	[illegible]	-	-	-	-
9	2'-0"	2'-0"	1'-0"	2'-0"	2'-0"	1'-0"	-	[illegible]	[illegible]	-	-	-	-
10	2'-0"	2'-0"	1'-0"	2'-0"	2'-0"	1'-0"	-	[illegible]	[illegible]	-	-	-	-
11	2'-0"	2'-0"	1'-0"	2'-0"	2'-0"	1'-0"	-	[illegible]	[illegible]	-	-	-	-
12	2'-0"	2'-0"	1'-0"	2'-0"	2'-0"	1'-0"	-	[illegible]	[illegible]	-	-	-	-

TYPICAL RETAINING WALL





FIRST FLOOR PLAN
SCALE: 1/4"=1'-0"



CELLAR FLOOR PLAN
SCALE: 1/4"=1'-0"

PROJECTION DETAILS

OFFICIAL

A © COPYRIGHT IS CLAIMED ON ALL OF THE DESIGNS, DETAILS AND INFORMATION ON THIS SHEET. COMMON LAW COPYRIGHT AND ALL OTHER INTELLECTUAL PROPERTY RIGHTS ARE RESERVED EXCLUSIVELY BY RICHARD TRAUB SPEIGHT. REPRODUCTION IN PART OR IN WHOLE OF BUILDING OR BUILDINGS FROM THESE PLANS WITHOUT THE EXPRESS WRITTEN PERMISSION OF RICHARD TRAUB SPEIGHT IS STRICTLY FORBIDDEN.

SPEIGHT ARCHITECTS
COLESPRING PLAZA SUITE 214
1001 SPRING STREET
SILVER SPRING, MD. 20910-4006
PHONE: (301) 589-1001


DATE: APRIL 9, 2002
DRAWN: R.T.S.
REVISIONS:

ZUCKERMAN BROTHERS, INC.
TWO WISCONSIN CIRCLE, SUITE 560
CHEVY CHASE, MARYLAND 20815
2900 ALBEMARLE STREET, N.W.
WASHINGTON, D.C. (202) 237-7022

DR.




FRONT ELEVATION
SCALE: 1/4"=1'-0"




SIDE ELEVATION
SCALE: 1/4"=1'-0"




STAIR SECTION
SCALE: 1/4"=1'-0"






TYPICAL RETAINING WALL



FIRST FLOOR PLAN
SCALE: 1/4"=1'-0"



CELLAR FLOOR PLAN
SCALE: 1/4"=1'-0"

PROJECTION DETAILS

ALL COPYRIGHT IS CLAIMED ON ALL OF THE ORIGINAL DETAILS AND INFORMATION ON THIS SHEET. COMMON LAW COPYRIGHT AND ALL OTHER APPLICABLE PROPERTY RIGHTS ARE RESERVED EXCLUSIVELY BY RICHARD TRAVIS SPEIGHT. REPRODUCTION IN PART OR IN WHOLE OF BUILDING OR RE-BUILDING FROM THESE PLANS WITHOUT THE EXPRESS WRITTEN PERMISSION OF RICHARD TRAVIS SPEIGHT IS STRICTLY FORBIDDEN.

CONDOMINIUM NUMBER

SPEIGHT ARCHITECTS
COLESPRING PLAZA SUITE 214
1001 SPRING STREET
SILVER SPRING, MD. 20910-4006
PHONE (301) 588-1001

DATE: APR. 9, 2002
DRAWN: R.T.S.
REVISIONS:

ZUCKERMAN BROTHERS, INC.
TWO WISCONSIN CIRCLE, SUITE 560
CHEVY CHASE, MARYLAND 20815
2902 ALBEMARLE STREET, N.W.
WASHINGTON, D.C. (202) 237-7022

OF: