



District of Columbia Fire & EMS Department
Fire Prevention Division
1100 4th Street SW, Suite: E-700
Washington, D.C. 20024-4451



RI1-Reinspection-1 Assigned To PINKNEY, Wendy on 5/25/2016

Start Date: 5/25/2016 11:36:25AM
Business Name: Elonda's Day Care
Address: 816 6th ST NE
City/State/Zip: Washington, DC 20002

Finish Date: 5/25/2016 11:37:02AM
Occupancy ID: 99841
Station No.:
Business Phone:

<u>Complex Info</u>	<u>Main Floor</u>	<u>Stories</u>	<u>Estimated Values</u>
Commercial Units: 0	Length: 0	Above Grade: 3	Property: \$0.00
Residential Units: 0	Width: 0	Below Grade: 1	Content: \$0.00
Complex Type: 4	Area: 0	Upper Construction: -	
Complex:	Construction: -		

An authorized representative of the Fire Chief of the District of Columbia Fire and EMS Department has observed the following violation(s) of the District of Columbia Fire Prevention Code at your premises.

ALL VIOLATIONS MUST BE ABATED IMMEDIATELY

<u>Violations</u>	<u>Date Found</u>	<u>Date Cleared</u>	<u>Standard/Reference</u>
-------------------	-------------------	---------------------	---------------------------

2012 IFC CH 10

ILLUMINATIONS - EXIT SIGN

5/20/2016

5/25/2016

Comment: Place an Exi sign at the Front and Rear door

{IFC 2012 International Code set}

[B] 1011.3 - [B] 1011.3 Illumination.: Exit signs shall be internally or externally illuminated.

Exception: Tactile signs required by Section 1011.4 need not be provided with illumination.

2012 IFC CH 07

SIGNS

5/20/2016

5/25/2016

Comment: Label doors Storage, Electrical Room etc.

{IFC 2012 International Code set}

703.2.1 - 703.2.1 Signs.: Where required by the fire code official, a sign shall be permanently displayed on or near each fire door in letters not less than 1 inch (25 mm) high to read as follows:

1. For doors designed to be kept normally open: FIRE DOOR—DO NOT BLOCK.
2. For doors designed to be kept normally closed: FIRE DOOR—KEEP CLOSED.

ABATED

ALL VIOLATIONS ABATED

5/25/2016

5/25/2016

APPROVAL GIVEN

APPROVAL GIVEN

5/25/2016

5/25/2016

Board of Zoning Adjustment
District of Columbia
CASE NO.19266
EXHIBIT NO.38

Start Date: 5/25/2016 11:36:25AM
Business Name: Elonda's Day Care
Address: 816 6th ST NE
City/State/Zip: Washington, DC 20002

Finish Date: 5/25/2016 11:37:02AM
Occupancy ID: 99841
Station No.:
Business Phone:

C23B6DF596678

**PENALTIES-SECTION 112
 FAILURE TO COMPLY WITH THE
 DISTRICT OF COLUMBIA FIRE CODE**

F-112.3 Penalty for Violations: Any person, firm or corporation violating any of the provisions of this code or failing to comply with any order issued pursuant to any section thereof, upon conviction thereof shall be punished by a fine of not more than three hundred dollars (\$300) or imprisonment for not more than ninety (90) days, or both. Each day that a violation continues, after a service of notice as provided in this code, shall be deemed a separate offense.

F-112.4 Civil Infractions: Civil fines, penalties, and fees may be imposed as alternative sanctions for any infraction of the provisions of this code, or any rules or regulations issued under authority of this code or pursuant to Title I-III of the Department of Consumer and Regulatory Affairs Civil Infractions Act of 1985, D.C. Law 6-42, D.C. Code sec.6-2700 et seq.

(NOTICE)

Notwithstanding the existence of the above penalties, any violation or attempted violation of this code may be restrained, corrected or abated, as the case may be, by injunction or other appropriate proceeding.

SECTION 113 APPEALS

DCMR 12H F-113.1 Right of Appeal. Any person directly affected by a notice or order issued under this *Fire Prevention Code* shall have the right to appeal to the Office of Administrative Hearings, pursuant to the Office of Administrative Hearings Act, effective March 6, 2002 (D.C. Law 14-76; D.C. Official Code §2-1831.01 *et seq.* and regulations promulgated thereunder. The appeal shall be filed within ten (10) days of the date of service of the notice or order. An appeal shall be based on a claim that the true intent of this code has been incorrectly interpreted, the provisions of the code do not fully apply, or the requirements of this code are adequately satisfied by other means. Appeals of notices (other than notices pursuant to Section F-110H (Unsafe Conditions) or section F-111H (Emergency Measures) shall stay the enforcement of the notice until the appeal is heard by the Office of Administrative Hearings.

Failure to remedy said violations will subject you to the penalties as prescribed by Section 112.2 and F-112.3 of the International Fire Code (2006) as amended by the D.C. Fire Prevention code Supplement (2008) (DCMR 12H) shall constitute the D.C. Fire Prevention Code (2008). If you do not understand any part of this notice, please contact this office at **(202) 727-1600**

Start Date: 5/25/2016 11:36:25AM
Business Name: Elonda's Day Care
Address: 816 6th ST NE
City/State/Zip: Washington, DC 20002

Finish Date: 5/25/2016 11:37:02AM
Occupancy ID: 99841
Station No.:
Business Phone:

Signature

Recipient:



Elonda Edwards

Owner

Inspector



Wendy Pinkney

Inspector

(202) 727-1600 (office)

(202) 727-3238 (fax)

www.fems.dc.gov

“Fire Sprinklers and Smoke Alarms Save Lives”