



⊕ INDICATES 1/2" CONCEALED PENDANT SPRINKLER. PROVIDE AUTOMATIC SPRINKLERS PER 2013 DISTRICT OF COLUMBIA FIRECODE: 903.3.1.3, NFPA 13d SPRINKLER SYSTEMS.

No.	Date	REVISIONS
1	01.05.21	REVISIONS
1. BZA SUBMISSION 08.12.20		
2. HPRB SUBMISSION 10.01.20		

RICHARD WILLIAMS ARCHITECTS, PLLC
 1909 Q STREET NW #200
 WASHINGTON, DC 20009
 202.387.4500

FLOOR PLANS

RWA Job No. 0000

Board of Zoning Adjustment
 District of Columbia
 CASE NO. 2019
 EXHIBIT NO. RA **A005**

