

Begin forwarded message:

From: DC Department of Buildings <dob@dc.gov>
Subject: Re: FW: Building Permit #B2504679
Date: December 9, 2025 at 4:28:02 PM EST
To: shawn@bfmarch.com
Reply-To: dob@dc.gov

Mr. Buehler: I talked to the supervisory team and they have determined that unless a minimum of 40% of the original envelope walls were kept on site, a new building must provide two 8ft. side yard setbacks; therefore, relief from the Board of Zoning adjustment will be required. Attached is the Zoning Administrator's interpretation 10: Demolition versus raze for Zoning purposes.

We can provide you with a BZA memorandum to support your BZA application. Additionally, we could reach out to the Board and ask them to prioritize your case.

Let us know if you any questions.

Ernesto Warren | Zoning Technician, Office of Zoning Administration
The Department of Buildings
ernesto.warren@dc.gov | 1100 4th St SW, DC 20024
main: 202.671.3500 | desk: 202.442.4505 | cell: 202.465.0409
dob.dc.gov

