



ZONING COMMISSION COMMENTS:
 The metal panels along 58th Street seem heavy. This elevation requires refinement and a possible reduction of the metal panel.

RESPONSE:
 A different profile has been chosen for the metal panel. The wall module at the metal panel has been reduced from 12" deep to 8" deep, allowing the face of the metal system to align with the face of the Quik Brik below. The bottom trim has been thinned and raised to align with the overflow scuppers. Treatment of the pilasters has been refined to provide more vertical emphasis in lieu of horizontal. Embedded "C" channels and precast caps have been incorporated.

