



NOTES:

1. REFRIGERANT LENGTH LIMITED TO 100' BASED ON MITSUBISHI BASIS OF DESIGN.
2. MANUFACTURER LIMITS INDOOR UNIT TO DUCTLESS TYPE.
3. 80 CONDENSING UNITS FROM 4TH FLOOR TO 1ST FLOOR WILL HAVE TO BE LOCATED IN THE GARAGE OR GROUND LEVEL.

1333 M STREET
DATE: 1/10/14

MECHANICAL ROOF PLAN - SLIM SPLIT SYSTEM

EX. D



| | | |
|--|---------------------------------------|---|
| | B E E | B E E |
| | UILT NVIRONMENT ENGINEERS, PLLC | MEP CONSULTANTS <small>4630 LEE HIGHWAY SUITE 201 ARLINGTON, VA 22207 703.886.0548 WWW.BEENERS.COM</small> |

ZONING COMMISSION
District of Columbia
CASE NO.13-12
EXHIBIT NO.34D